



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada - Pacific
Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet Float Reconstruction	
Solicitation No. - N° de l'invitation F1571-188003/A	Amendment No. - N° modif. 001
Client Reference No. - N° de référence du client F1571-188003	Date 2018-08-13
GETS Reference No. - N° de référence de SEAG PW-\$PWY-036-8395	
File No. - N° de dossier PWY-8-41070 (036)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2018-08-20	Time Zone Fuseau horaire Pacific Daylight Saving Time PDT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Martin (PWY), Delia	Buyer Id - Id de l'acheteur pwy036
Telephone No. - N° de téléphone (778) 707-2139 ()	FAX No. - N° de FAX (604) 775-6633
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: DFO - Port Alberni Small Craft Harbour - Port Alberni, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation. - N° de l'off. à comm.
F1571-188003/A

Amd. No. - N° de la modif.
001

Buyer ID - Id de l'acheteur
pwy036

Client Ref. No. - N° de réf. du client

File No. - N° du dossier
PWY-8-41070

CCC No./N° CCC - FMS No/ N° VME

Les documents français seront disponibles sur demande.

This Amendment #001 is raised to:

Issue Addendum No. 1.

Please see Addendum No. 1 attached.

The addendum will form part of the contract documents.

All other terms and conditions remain unchanged.

The following changes / clarifications in the tender documents are effective immediately. This Addendum will form part of the Contract Documents.

1.0 Response to Bidders' Inquiries:

- 1.1 Please find below a response to bidder's inquiries received as of 10:00am PST, Aug 13th, 2018.

Q1: What fungicide can be used on the piles?

A1: Examples of fungicide include: Bora-Care and Cobra Rods Fungicide.

Q2: Will there be a laydown area that material can be stored onsite during construction?

A2: Yes, bidders shall assume a laydown area will be provided on the wharf. The specific size and location will be provided after award.

Q3: What are the sizes of the concrete panels?

A3: Typical concrete panel sizes are provided on Drawing PA-FR-002.

Q4: Will the new joists be the Standard "DPW" float kit materials?

A4: Refer to Specifications Section 01 11 00, 4.5.2.2. The contractor is required to supply and install new ACZA salt treated timber joists. Joists shall be field treated where cut or drilled, as per Section 00 99 00.

Q5: How many risers shall we allow for in the 100m of bull rail to be replaced?

A5: Bidders shall assume riser blocks are required every 1.5m. The exact number of riser blocks required shall be determined during the Contractor's site visit, as part of item 4.5.1.1.

Q6: What length should the Fascia Boards be supplied in?

A6: Fascia Boards shall be supplied minimum 6.09m (20 feet) long. New Fascia Boards shall be custom cut to match the length of the replaced fascia boards.

Q7: Is the decking to be surfaced S1S2E?

A7: Yes.

2.0 Specification Amendments

2.1 Refer to Specifications, Summary of Work - Section 01 11 00, 4.5.2.1:

Delete Clause 4.5.2.1.1:

“Some hardware has already been removed from the concrete panels. Bidders shall assume 10% of hardware has been removed and therefore, a credit for this shall be applied to this item.”

Add Clause 4.5.2.1.1:

“All hardware securing the concrete panels has been disconnected. Therefore, this work shall not be included in this item.”