



**RETURN BIDS TO:
RETOURNER LES SOUMISSIONS A:
Bid Receiving/Réception des
sousmissions**

**RCMP / GRC
Procurement & Contracting services
c/o Commissionaires, F Division
6101 Dewdney Avenue
Regina, SK S4P 3K7**

**Facsimile Number for Amendments:
(306) 780-5232**

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

**The referenced document is hereby
revised; unless otherwise indicated, all
other terms and conditions remain the
same.**

**Ce document est par la présente révisé;
sauf indication contraire, les modalités
de l'invitation demeurent les memes.**

Comments - Commentaries

**Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur**

Facsimile No. - No de télécopieur:

Telephone No. - no de téléphone:

Title-Sujet Interior Renovations	
Solicitation No. - No. de l'invitation M5000-19-0814/A	Date 15 August 2018
Amendment No. - No modif. 04	
Client Reference No. - No. De Référence du Client M5000-19-0814/A	
GETS Reference No. - No. de Référence de SEAG PW-18-00837727	
Solicitation Closes -L'invitation prend fin at - à 2 :00 pm Central Standard Time on - le 21 August 2018	
F.O.B. - F.A.B. Destination	
Address Enquiries to: - Adresser toutes questions à: Teresa Hengen, Procurement Officer	
Telephone No. - No de téléphone (639) 625-3449	Fax No. - N° de FAX: (306) 780-5232
Destination of Goods, Services, and Construction: Destinations des biens, services et construction: Royal Canadian Mounted Police Detachment 10512 101 Ave Morinville, AB	
This document does not contain a PERSONNEL SECURITY Clearance requirements	
Delivery Required - Livraison exigée: See Herein Voir aux présentes	Delivery Offered - Livraison proposée
Name and title of person authorized to sign on behalf of Vendor/Firm Nom et titre de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur	



This amendment is raised to address the following:

Q5) Is there a specific colour you want for the Tectum panels? They can come pre-painted in white or we can order them without colour and paint any colour on site.

R5) No colour specified, but should be neutral, and can be selected by local Detachment Commander or delegate

Q6) There is a note in the spec that states both interview rooms are to receive the Tectum panels. Can you confirm if both are required, or if it is only the small one by the cells?

R6) general spec was used which will be adjusted in the future. There is only the one room being soundproofed as described in the SOW

Q8) Can the low voltage cables for the monitoring system be ran free air in the ceiling space?

R8) No, refer to previous questions asked

Q9) For disconnecting and reconnecting the camera's when we run the new lines, do you have a security company for the building that will do this?

R9) RCMP has approved contractors for this function, this can be completed outside the contract, just provide a pull the wire/conduit.

Q10) Is there a telephone system that needs to be tied into or telephone company that is contractor to work in the building as we have 1 new telephone line to install.

R10) Installing the line and running the wire is to be completed by the contractor, another contractor would be completing the connection

Q11) Usually these rooms only need to meet an STC of 46. To achieve this the doors are designed at an STC rating of 51. Room itself will not be able to achieve 51 with only a single door. Could you confirm if the room itself does in fact need to be 51, or if 46 is the standard?

R11) We request STC51 in order to achieve a minimum of 46.