

Canada Parks Agency
Rehabilitation Lachine Canal Walls
Repair and replacement of crowning
walls (Areas I.7, I.8, and I.9 – Reach No 4)
Project N° CLAC-1455-09
Addendum n° 02

THIS ADDENDUM COMPLETES, MODIFIES OR ELIMINATES CERTAIN ELEMENTS OF THE TENDER DOCUMENTS, WHICH THE ADDENDUM REFERS TO. IT IS AN INTEGRAL PART OF THE TENDER DOCUMENTS.

MODIFICATIONS ON PLANS AND SPECIFICATIONS

The current precisions are provided, following questions received from contractors during the site visit, and other written questions received.

1. PRECISIONS

1.1 Quality Control of Concrete

The Contractor must immediately notify the Supervisor of any results outside the tolerances during concrete tests on site. The Contractor must also provide the Supervisor with written results of these tests within a maximum of 24 hours. In addition, results of compression tests performed at 7 days and 28 days must also be sent to the Supervisor within 24 hours of their completion.

Prepared by :

Carlos Villate, ing.
Ponts et ouvrages d'art
Stantec Experts-Conseils ltée.

Reviewed and approved by :

Martin Lessard, ing.
Ponts et ouvrages d'art
Stantec Experts-Conseils ltée.