



**RETURN BIDS TO:**  
**RETOURNER LES SOUMISSIONS Á:**  
**Parks Canada Agency Bid Receiving Unit**  
**National Contracting Services**  
**220 - 4 Avenue S.E., suite 720**  
**Calgary, AB T2G 4X3**  
**Bid Fax: (866)246-6893**

**AMENDMENT /  
 MODIFICATION 007**

**Tender To: Parks Canada Agency**  
 We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services, and construction listed herein and on any attached sheets at the price(s) set out therefor.

**Soumission aux: l'Agence Parcs Canada**

Nous offrons par la présente de vendre à Sa Majesté la Reine du Chef du Canada, aux conditions énoncées ou incluses par référence dans la présente at aux annexes ci-jointes, les biens, services et construction énumérés ici et sur toute feuille ci-annexée, au(x) prix indiqué(s).

Comments - Commentaries

Vendor/Firm Name and Address  
 Raison sociale et adresse du fournisseur/de l'entrepreneur

**Issuing Office - Bureau de distribution**

**Parks Canada Agency**  
**220 - 4 Avenue S.E., suite 720**  
**Calgary, AB T2G 4X3**  
**Bid Fax: (866)246-6893**

<b>Title-Sujet</b> Tunnel Mountain Village 1 Rehabilitation – Banff National Park		
<b>Solicitation No. - No. de l'invitation</b> 5P420-18-0210/A	<b>Date:</b> August 20, 2018	
<b>GETS Reference No. – No de reference de SEAG</b> PW-18-00836655	<b>Amendment No. - N° de la modif.</b> 007	
<b>Solicitation Closes:</b>		
<b>at – á</b> 02:00 PM	<b>on – le</b> August 23, 2018	<b>Time Zone - Fuseau horaire</b> MDT - HAR
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>		
<b>Address Inquiries to: - Adresser toute demande de renseignements à :</b> Andrea Major    andrea.major@pc.gc.ca		
<b>Telephone No. - No de téléphone</b> (403) 292-5451	<b>Fax No. – No de FAX:</b> (866) 246-6893	
<b>Destination of Goods, Services, and Construction:</b> <b>Destinations des biens, services et construction:</b>  See Herein – Voir ici		

**TO BE COMPLETED BY THE BIDDER (type or print)**

<b>Vendor/Firm Name</b>	
<b>Address - Adresse</b>	
<b>Name of person authorized to sign on behalf of the Vendor/Firm</b> <b>Nom de la personne autorisée a signer au nom du fournisseur/ de l'entrepreneur</b>	
<b>Titale - Titre</b>	
<b>Telephone No. - N° de telephone:</b>	_____
<b>Facsimile No. - N° de télécopieur:</b>	_____
<b>Signature</b>	<b>Date</b>

## Amendment 007

This amendment is being raised to amend the tender package, and distribute questions and answers submitted via email.

### A) QUESTIONS AND ANSWERS

- Q1. With the new information from Addendum #4, Fortis wants the primary to be 2.5m away from water and sanitary, it make sense to have the Fortis conduit furthest away from the deep utilities and the gas, lighting, and coms towards them (which is opposed to the cross sections on drawing C-301). Is that acceptable?
- A1. Yes, pending the minimum separation requirements are still met between all utilities, including between all shallow utilities and the Fortis primary line.
- Q2. Drawings C-202 to C-216 – On the **plan view** of the drawing the existing sanitary pipe is shown as PVC, but on all the **profiles** on the same pages it is shown as concrete, which is correct?
- A2. The plan/profile drawings showing all existing sanitary pipe as PVC and concrete is incorrect. Existing sanitary pipe material and conditions are shown on the additional drawings C-101 and C-102 (separate from design drawing package) which summarize the findings of the pre-design investigative CCTV.
- Q3. For the existing water I have seen both D.I and PVC, any idea of how much of each is expected (ie. Mostly D.I and a small amount of PVC)?
- A3. The materials identified for the existing water system on drawing C 105 and C 106 are the most accurate information available. The contractor shall be aware that the existing system has undergone extensive undocumented repairs since first installed and is highly likely to have changes from what is shown on the drawings.

## **B) TENDER PACKAGE REVISIONS**

### **1. SPECIFICATIONS**

The following sections have been revised.

**In Section** 01 11 00, Clauses 1.7.5.1

**DELETE:** Construction may commence after September 4th, 2018

**INSERT:** Construction may commence after September 4th, 2018 in Loops A, B, C, D and other areas not affecting operation of the northern campground loops. Construction on main access road, kiosk area and water/sanitary service required for Loops E, F, G, H, J & K may commence after September 10, 2018.

**In Section** 01 11 00, Clauses 1.7.5.2

**DELETE:** Construction may commence after September 4th, 2018

**ADD:** Construction may commence after September 10, 2018.

**All other terms and conditions remain unchanged.**