



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Travaux publics et Services gouvernementaux
Canada

Place Bonaventure, portail Sud-Oue

800, rue de La Gauchetière Ouest

7^e étage, suite 7300

Montréal

Québec

H5A 1L6

FAX pour soumissions: (514) 496-3822

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address

Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Travaux publics et Services gouvernementaux Canada

Place Bonaventure, portail Sud-Oue

800, rue de La Gauchetière Ouest

7^e étage, suite 7300

Montréal

Québec

H5A 1L6

Title - Sujet Réfect. toitures bâtiment principal	
Solicitation No. - N° de l'invitation EF236-191056/A	Amendment No. - N° modif. 001
Client Reference No. - N° de référence du client R.091106.001	Date 2018-08-21
GETS Reference No. - N° de référence de SEAG PW-\$MTC-035-14985	
File No. - N° de dossier MTC-8-41102 (035)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2018-08-27	Time Zone Fuseau horaire Heure Avancée de l'Est HAE
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Lussier, Joël	Buyer Id - Id de l'acheteur mtc035
Telephone No. - N° de téléphone (514) 708-3582 ()	FAX No. - N° de FAX (514) 496-3822
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

August 20th 2018

PROJECT : PWGSC - PSPC
Agriculture and Agri-Food Canada
Research and Development Centre
Roofs Refection of the Main Building, lots 1, 3 and 4
Solicitation no : EF236-191056/A
PWGSC Reference no : R.091106.001
N/D : 180108

ADDENDUM N° A-1

This document is an integral part of the bid documents.

ARCHITECTURE :

SPECIFICATIONS

1.0 Section 07 52 00 – Modified Bituminous Membrane Roofing

- .1 In article 3.13 Roof drain installation, add the following point:
 - .2 *When roof drains are easily accessible by the ceiling plenum and work does not interfere with occupant activities, ensure sealing with the downspout and with a flexible coupling sleeve. The Departmental Representative reserves the right to require a donut seal for sealing purposes.*

2.0 Section 07 52 01 – Protected Modified Bituminous Membrane Roofing

- .1 In article 3.10 Roof drain installation, add the following point:
 - .2 *When roof drains are easily accessible by the ceiling plenum and work does not interfere with occupant activities, ensure sealing with the downspout and with a flexible coupling sleeve. The Departmental Representative reserves the right to require a donut seal for sealing purposes.*

3.0 Section 07 55 63 – Vegetated protected Membrane Roofing

- .1 In article 2.18 Roof drain, add the following point:
 - .2 *Flexible coupling sleeve or donut seal according to site conditions.*
- .2 In article 3.10 Roof drain installation, add the following point:
 - .2 *When roof drains are easily accessible by the ceiling plenum and work does not interfere with occupant activities, ensure sealing with the downspout and with a flexible coupling sleeve. The Departmental Representative reserves the right to require a donut seal for sealing purposes.*

4.0 Section 02 41 00.08 – Demolition – Minor Works

- .1 In article 3.3 Site restoration & repairs, point 5, add the following phrase :
Use new plants (trees, shrubs, perennials...).
- .2 Add article 3.5 as follows :
3.5 MOTORIZED EQUIPMENT
 - .1 *Motorized equipment (such as Bobcats) will only be authorized in basin 3. They will have to be caterpillar loaders and used for gravel removal only. They must circulate on existing insulation at all times.*
 - .2 *Upon contract award, it is Contractor's responsibility to ensure the roof's bearing capacity for this equipment. Provide written proof signed and sealed by a structural engineer, member of the OIQ.*

DRAWINGS – LOT 1

1.0 Sheet A01/17 – Site Plan

- .1 Storage of materials and trailer must be located at the rear of the building and must be located on the grassed area, at the right hand side of the identified area.

2.0 Sheets A05/17, A06/17 et A07/17 – Construction – roof plan

- .1 In the legend CONSTRUCTION – GENERAL NOTES, add the following note:
'5- For all remaining existing metal flashings, remove existing sealants, clean, properly prepare surface and apply a new color sealant to match substrate.

DRAWINGS – LOT 3

1.0 Sheet A01/17 – Site Plan

- .1 Storage of materials and trailer must be located at the rear of the building and must be located on the grassed area, at the right hand side of the identified area.

2.0 Sheets A04/10 and A05/10 – Construction – roof plan

- .1 At the legend CONSTRUCTION – GENERAL NOTES, add the note as following :
4- For all remaining existing metal flashings, remove existing sealants, clean, properly prepare surface and apply a new color sealant to match substrate.

DRAWINGS – LOT 4

1.0 Sheet A01/17 – Site Plan

- .1 Storage of materials and trailer must be located at the rear of the building and must be located on the grassed area, at the right hand side of the identified area.

2.0 Sheet A02/09 – Demolition – roof plan

- .1 Two (2) existing air intakes: metal frame on supports to be temporarily supported on top of existing insulation. Provide a \pm 6150 x 1250mm frame with 8 brackets and a \pm 1690 x 1245mm frame with 5 brackets.

3.0 Sheet A03/09 – Construction – roof plan

- .1 In the legend CONSTRUCTION – GENERAL NOTES, add the following note :
4- For all remaining existing metal flashings, remove existing sealants, clean, properly prepare surface and apply a new color sealant to match substrate.
- .2 Existing air intakes, adjust brackets. Provide a \pm 6150 x 1250mm frame with 8 brackets and a \pm 1690 x 1245mm frame with 5 brackets.

END OF ADDENDUM

BISSON FORTIN ARCHITECTURE+DESIGN



Danielle Bisson, architecte associée PA LEED BD+C
DB/bc