



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS Á:

**Parks Canada Agency
3 passage du Chien-d'Or
Québec, Qc G1R 3Z8**

AMENDMENT #3

Tender To: Parks Canada Agency

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services, and construction listed herein and on any attached sheets at the price(s) set out therefor.

Soumission aux: l'Agence Parcs Canada

Nous offrons par la présente de vendre à Sa Majesté la Reine du Chef du Canada, aux conditions énoncées ou incluses par référence dans la présente et aux annexes ci-jointes, les biens, services et construction énumérés ici et sur toute feuille ci-annexée, au(x) prix indiqué(s).

Comments - Commentaries

Vendor/Firm Name and Address
Raison sociale et adresse du fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

**Parks Canada Agency
3 passage du Chien-d'Or
Québec, Qc G1R 3Z8**

Title-Sujet Grounds Repairs and Drainage - ``Forge Basse`` and ``Fontaine du Diable`` Sectors, Forges Du Saint-Maurice NHS		
Solicitation No. - No. de l'invitation 5P201-18-0110/A		Date: August 23rd 2018
GETS Reference No. - No de reference de SEAG PW-18-00835819		Client Ref. No. - No. de réf du client. 1857
Solicitation Closes - L'invitation prend fin :		
at - à 2:00 PM	on - le August 24th 2018	Time Zone - Fuseau horaire EDT
F.O.B. - F.A.B.		
Plant-Usine: <input type="checkbox"/>	Destination: <input checked="" type="checkbox"/>	Other-Autre: <input type="checkbox"/>
Address Inquiries to: - Adresser toute demande de renseignements à : Josée Gagnon josee.gagnon@pc.gc.ca		
Telephone No. - No de téléphone (418) 648-2502		Fax No. - No de FAX: (418) 649-6971
Destination of Goods, Services, and Construction: Destinations des biens, services et construction: See Herein - Voir aux présentes		

TO BE COMPLETED BY THE BIDDER (type or print)
À ÊTRE COMPLÉTER PAR LE SOUMISSIONNAIRE (taper ou écrire en caractères d'imprimerie)

Vendor/Firm Name - Nom du fournisseur/de l'entrepreneur	
Address - Adresse	
Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur	
Titale - Titre	
Telephone No. - N° de téléphone: _____	
Facsimile No. - N° de télécopieur: _____	
Signature	Date

AMENDMENT #3

THE PURPOSE OF THIS AMENDMENT TO PROVIDE DETAILS TO THE TECHNICAL SPECIFICATIONS, TO PROVIDE THE ANSWERS TO QUESTIONS ASKED BY POTENTIAL BIDDERS AND TO EXTEND THE BID CLOSING DATE.

1. YOU MUST CONSIDER THE INFORMATION IN THE ENVIRONMENTAL SPECIFICATIONS BELOW, LOCATED IN THE ATTACHMENTS SECTION, IN THE EVALUATION OF YOUR BID.

DevisEnvironnement_Route_1-2-3_Final_R1.pdf

2. QUESTIONS AND ANSWERS:

Q2. At the Fontaine du Diable site, there are dead and/or sick trees that are very degraded. Are we required to cut and dispose of them? See picture below.



A2. Yes.

Q3. At the Fontaine du Diable site, near the 300mm pipe discharge, there are four (4) logs on the ground in the surrounding woodland. Would these require removal and disposal? See picture below.



A3. Yes.

Q4. Can we recover the stones from the dismantled development area at the Fontaine du Diable site for use as ditch rock and culvert outfalls? See picture below.



A4. No, we are asking for ditch riprap and culvert outings to be washed round stone.

Q5. There is a pile of MG20 on site along the access road just before the 1,800 mm culvert. Can we use it for temporary works? See picture below.



A5. Yes.

Q6. According to the general clauses, site installation, section 01 52 00, 1.7, it is indicated to provide a cell phone to the supervisor of Parks Canada. Are we really required to provide this since the supervisor probably already has his own cell phone today in 2018?

A6. No, it is not necessary to provide a cell phone to the Parks Canada site supervisor.

Q7. According to the general clauses, site installation, section 01 52 00, 1.6, it is indicated to provide security guard services while access to the site is controlled by a gate, and access to the road works is also controlled by a gate. Is it really required?

A7. Yes, a security guard must be at the fence at all times since the site will be closed to visitors during the work.

Q8. Concerning the 1,800 mm culvert which has a load limit is 5 tons: can a temporary structure be constructed (steel plates over the road infrastructure) with signed and sealed plans to be able to distribute the load to increase capacity?

A8. Yes, with signed and sealed plans.

Q9. Will a site trailer really be required during the work or will Parks Canada be using the work location to left of the entrance of the Forges site?
If so, have you ever stopped a work site for installation? Otherwise, we suggest the parking lot near the access road entrance.

A9. Yes, the trailer can be installed in the parking lot near the access road entrance.

Q10. We cannot find the document which Section 01 35 43 Environmental Protection refers to. Is it possible to have a copy and if so, what clauses or statements of this document would be applicable to the execution of this contract?

A10. See attached document: [DevisEnvironnement_Route_1-2-3_Final_R1.pdf](#)

Q11. Given the requirement of some information in addition to the delay in obtaining certain material prices, would it be possible to extend the bid closing date by a working week? This would allow us to further refine bid prices.

A11. No, the bid opening has already been postponed twice and given the limited time for completion of the work between September 04 and September 14 due to the fish habitat requirements, the opening of bids will be the Friday August 24th, 2018 at 2pm EDT.

THE BID CLOSING DATE IS EXTENDED TO FRIDAY THE 24TH OF AUGUST 2018, 2PM (EDT).

End of section.

ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED.

A signed copy of this amendment should accompany each tender. If your tender has already been submitted please sign and fax the amendment along with any revisions to tender price, to this office before the close of Tender to fax number (418) 649-6971.