




- CIRCUIT NOTES:
1. SUPPLY AND INSTALL NEW 20 AMP 1 POLE CIRCUIT BREAKERS (3 SUCH) C/W MOUNTING HARDWARE WITHIN EXISTING PANEL. IC RATING TO MATCH, FOR NEW 20 AMP RECEPTACLES AT NEW PEDESTAL. (#8 CONDUCTORS)
 2. SUPPLY AND INSTALL NEW 30 AMP 2 POLE CIRCUIT BREAKER C/W MOUNTING HARDWARE WITHIN EXISTING PANEL. IC RATING TO MATCH, FOR NEW 30 AMP RECEPTACLE AT NEW PEDESTAL. (#8 CONDUCTORS) COORDINATE ON SITE.
 3. SUPPLY AND INSTALL NEW 15 AMP 1 POLE CIRCUIT BREAKER C/W MOUNTING HARDWARE WITHIN EXISTING PANEL. IC RATING TO MATCH, FOR NEW 15 AMP RECEPTACLE AT NEW PEDESTAL. (#8 CONDUCTORS) COORDINATE ON SITE.
 4. SUPPLY AND INSTALL NEW 15 AMP 1 POLE CIRCUIT BREAKER C/W MOUNTING HARDWARE WITHIN EXISTING PANEL. IC RATING TO MATCH, FOR LIGHTING FIXTURES AT NEW LIGHT POLE. (#10 CONDUCTORS) COORDINATE ON SITE.
 5. SUPPLY AND INSTALL NEW MULTI-CIRCUIT METERING EQUIPMENT WITHIN ELECTRICAL ROOM NEAR EXISTING PANEL. SEE NEW MULTI-CIRCUIT ENERGY METER NOTES ON DRAWING E2.

SMALL CRAFT HARBOURS



NOTES:

1. DO NOT SCALE FROM THIS DRAWING.
2. CONTRACTOR TO VERIFY ALL DIMENSIONS ON SITE BEFORE PROCEEDING WITH THIS WORK.
3. ALL WORK TO BE IN ACCORDANCE WITH THE LATEST REQUIREMENTS OF: THE NATIONAL BUILDING CODE OF CANADA, LATEST EDITION; CANADIAN ELECTRICAL CODE, CURRENT EDITION; ANY OTHER AUTHORITIES HAVING JURISDICTION.



0	ISSUED FOR TENDER	27/06/18
A	ISSUED FOR REVIEW	08/03/18
revisions		date

project
WHARF RECONSTRUCTION
MUSGRAVE HARBOUR, NL
project

drawing
dessin

WHARF PLAN & DETAILS

designed K.N.	conçu
date JUNE 2018	
drawn M.N.	dessiné
date JUNE 2018	
approved	approuvé
Tender Paul Curran	Soumission
DFO Project Manager	
project number 711872/721941	no. du projet
drawing no. E3	no. du dessin