

P/N: 711872/721941

Wharf Reconstruction

Musgrave Harbour, NL

Page 1

2018-02-02

PART 1 - GENERAL

1.1 REFERENCES

- .1 Canadian Standards Association (CSA):
 - 1. CAN/CSA-015-90, Wood Utility Poles and Reinforcing Stubs.
 - 2. American National Standards Institute (ANSI).
 - 3. Excavating, Trenching and Backfilling.
 - 4. Common Work Results - Electrical: Section 26 05 01.

1.2 PRODUCT DATA

- .1 Submit product data in accordance with Specification Section 01 33 00 - Submittal Procedures.

1.3 SHOP DRAWINGS

- .1 Submit shop drawings in accordance with Specification Section 01 33 00 - Submittal Procedures.

PART 2 - PRODUCTS

2.1 MATERIALS

- .1 Wood preservation: to CAN/CSA080 Series.

2.2 POLES

- .1 Wood utility poles: to CAN/CSA-015, wood species, Class 1, 10.5 meter poles, CCA pressure treated to 080-M1983. Installation as detailed on civil drawings.
 - 1. 10.5 m long poles for lighting fixtures.
 - 2. Minimum circumference at top - 635 mm.
 - 3. Minimum circumference at 1.8 m from butt - 978 mm.
- .2 Contractor to supply all mounting hardware, wiring, conduit, leg bolts, etc. as required.

P/N: 711872/721941
Wharf Reconstruction
Musgrave Harbour, NL

Page 2
2018-02-02

2.3 EQUIPMENT
IDENTIFICATION

.1 Rustproof number nails with 50 mm high
designated number and data installed.

PART 3 - EXECUTION

3.1 INSTALLATION

.1 Wooden light poles in concrete deck
installation shall be as outlined on Civil
drawings and in Civil specification.
Coordinate with General Contractor.

.2 Install owner supplied lights on wooden
poles in concrete deck as indicated.