



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS Á:

Parks Canada Agency
220 4 Ave SE, Suite 720
Calgary, AB T2G 4X3
Bid Fax: 1-866-246-6893

AMENDMENT / MODIFICATION

002

Tender To: Parks Canada Agency

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services, and construction listed herein and on any attached sheets at the price(s) set out therefor.

Soumission aux: l'Agence Parcs Canada

Nous offrons par la présente de vendre à Sa Majesté la Reine du Chef du Canada, aux conditions énoncées ou incluses par référence dans la présente at aux annexes ci-jointes, les biens, services et construction énumérés ici et sur toute feuille ci-annexée, au(x) prix indiqué(s).

Comments - Commentaries

Vendor/Firm Name and Address

Raison sociale et adresse du fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Parks Canada Agency
220 4 Ave SE, Suite 720
Calgary, AB T2G 4X3
Bid Fax: 1-866-246-6893

Title-Sujet Tangle Camp Decommissioning – Jasper National Park		
Solicitation No. - No. de l'invitation 5P420-18-0245/A		Date: August 28, 2018
GETS Reference No. – No de reference de SEAG PW-18-00838267		Amendment No. - N° de la modif. 2
Solicitation Closes:		
at – á 02:00 PM	on – le August 30, 2018	Time Zone - Fuseau horaire MDT - HAR
F.O.B. - F.A.B.		
Plant-Usine: <input type="checkbox"/>	Destination: <input checked="" type="checkbox"/>	Other-Autre: <input type="checkbox"/>
Address Inquiries to: - Adresser toute demande de renseignements à : Rebecca Chen		
Telephone No. - No de téléphone (403) 292-8509		Fax No. – No de FAX: 1-866-246-6893
Destination of Goods, Services, and Construction: Destinations des biens, services et construction: See Herein – Voir ici		

TO BE COMPLETED BY THE BIDDER (type or print)

Vendor/Firm Name	
Address - Adresse	
Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée a signer au nom du fournisseur/ de l'entrepreneur	
Titale - Titre	
Telephone No. - N° de telephone: _____	
Facsimile No. - N° de télécopieur: _____	
Signature	Date

IMPORTANT NOTICE TO BIDDERS

Parks Canada has relocated its office to:

**Parks Canada Agency Bid Receiving Unit
National Contracting Services
220 - 4 Avenue S.E., suite 720
Calgary, AB T2G 4X3**

It is the Bidder's responsibility to ensure that its bid is delivered on time to the appropriate address as identified on the cover page.

Amendment 02

This amendment is being raised to extend the solicitation closing date and to distribute questions and answers.

A) BID CLOSING DATE

The closing date for tender 5P420-18-0245/A is extended from August 29 2018 to **August 30, 2018 at 2:00PM Mountain Daylight Time (MDT).**

B) QUESTIONS & ANSWERS

Q26 Addendum 1 page 5 of 6 Q5-A5 and Q6-A6 reference Section Earthwork Shortform 32.91.19.21. Should that be Section 32.91.19.12?

Q26 Yes, the Section should be referenced as 32.91.19.12 - Earthwork Shortform, not 32.91.19.21

Q27 Section 32.91.19.12 identifies that the topsoil is available on site

- a. Is there backfill materials available on site other than topsoil or is the contractor required to import from off site.
- b. If the contractor is required to import backfill other than topsoil from off site can the backfill be imported from outside the Park boundaries?

A27 a. There are other backfill materials available on site, but assume that more than 50% of materials required for this project would be imported from off site. Parks Canada Agency Representative will identify which materials will be available and which are not available on site upon award.

b. The backfill can be imported from outside the Park boundaries upon approval of Parks Canada Agency Representative Environmental Safety Officer assigned to this project upon award. There may also be some materials sourced within the Park boundary at a location known as "Ranger Pit South" along the 93 Highway north of Tangle Camp's site. Materials and quantities available at "Ranger Pit South" are unknown and not yet verified.

Q28 Since the Haz Report was done in 2005, and using the identified risk levels and disposals procedures in the report, which no longer apply (Asbestos updated in 2012 and Lead in 2013) should we be remediating using the identified risk and contamination levels identified in the Haz Report, or using the current government standards?

A28 Though this report was provided in 2005, please use the identified risk levels and contamination disposal procedures from the most recent and current government standards for this project.

Q29 As per Earth Tech's site plan on figure 2, there is an indication of 3 septic tanks. Please advise which tanks are to be removed as only 1 was discussed at the site visit.

A29 Any septic tanks that are connected or had serviced the bunkhouse is to be removed. The septic tank that is connected or associated with the mechanic's garage is to remain since this building is not included in the scope of work.

Q30 Please indicate the composition of each septic tank. (Steel, fiberglass, etc.)

A30 Materials for any septic tanks on site are unknown.

Q31 Can the clean highway fill located at site be used to fill in the 2 voids left by the removal of contaminated soil ? (Upon a satisfactory sample analysis that all hazards have been removed)

A31 Yes the clean highway fill located on site can be used to fill any voids left by the removal of contaminated soil, except the smaller grade material that will be identified by Parks Canada Agency Representative upon award.

Q32 Is it possible to substitute the top soil for screened compost? The compost is from the Jasper WWTP and has been cleared both in class brackets A and B by the CMME.

A32 Certain compost can be substituted or acceptable upon approval of Parks Canada Agency Representative Environmental Safety Officer, but any compost from Waste Water Treatment Plants are not acceptable.

All other terms and conditions remain unchanged.