



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada - Pacific
Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet Hangar Bridge Walkway & Vestibule	
Solicitation No. - N° de l'invitation F1700-186926/A	Amendment No. - N° modif. 001
Client Reference No. - N° de référence du client F1700-186926	Date 2018-08-30
GETS Reference No. - N° de référence de SEAG PW-\$PWY-025-8407	
File No. - N° de dossier PWY-8-41073 (025)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2018-09-05	Time Zone Fuseau horaire Pacific Daylight Saving Time PDT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Fung, Donna(PWY)	Buyer Id - Id de l'acheteur pwy025
Telephone No. - N° de téléphone (604) 671-9689 ()	FAX No. - N° de FAX (604) 775-6633
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: DFO - Institute of Ocean Sciences - Sidney, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation
F1700-186926/A

Amd. No. - N° de la modif.
001

Buyer ID - Id de l'acheteur
PWY025

Client Ref. No. - N° de réf. du client

File No. - N° du dossier
PWY-8-41073

CCC No./N° CCC - FMS No./N° VME

This Amendment 001 is raised to issue Addendum No. 1

See Addendum No. 1 below.

ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED.

Addendum No.1

Date: August 29, 2018

Description: Hangar Bridge Walkway

This addendum is in addition to and forms part of the Contract. The cost, if any, of this revision(s) shall be included in the Contract Price. The revision(s) is as follows:

General Inquiries/Clarifications:

Question 1: Can you please have the consultant specify the conduit size for the Access Control?


Answer 1: 21mm

Question 2: There is a conflict between the drawings and specifications with respect to the FRP grating.

- Detail 2/S2.01 has a note showing the thickness is 50mm, while Specification 06 61 10 shows 38mm deep
- Also the specification calls up both 38mm square mesh and 19mm square mesh. Can you clarify?

Answer 2:

- FRP is to be 50mm deep
- See illustration below for clarification of 19mm top and 38mm bottom only



End of Addendum No.1