



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS Á:

**Parks Canada Agency
Banff Field Unit
PO Box 900
216 Hawk Avenue
Banff, AB, T1L 1K2**

AMENDMENT #2 TO:

INVITATION TO TENDER

APPEL D'OFFRES

Tender To: Parks Canada Agency
We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services, and construction listed herein and on any attached sheets at the price(s) set out therefor.

Soumission aux: l'Agence Parcs Canada
Nous offrons par la présente de vendre à Sa Majesté la Reine du Chef du Canada, aux conditions énoncées ou incluses par référence dans la présente at aux annexes ci-jointes, les biens, services et construction énumérés ici et sur toute feuille ci-annexée, au(x) prix indiqué(s).

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

**Parks Canada Agency
Banff National Park
PO Box 900
Banff, AB
T1L 1K2**

Title-Sujet Mountain Avenue Parking Lots and Intersection Improvements – Banff National Park		
Solicitation No. - No. de l'invitation 5P421-18-1057/A		Date: August 31, 2018
GETS Reference No. – No de reference de SEAG PW-18-00839661		Client Ref. No. – No. de réf du client. 696b
Solicitation Closes:		
at – à 02:00 PM	on – le September 6, 2018	Time Zone - Fuseau horaire MDT - HAR
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>		
Address Inquiries to: - Adresser toute demande de renseignements à : Rose Marino rose.marino@pc.gc.ca		
Telephone No. - No de téléphone (403) 760-1319		Fax No. – No de FAX: 403-762-5057
Destination of Goods, Services, and Construction: Destinations des biens, services et construction: See Herein – Voir ci-joint		

TO BE COMPLETED BY THE BIDDER (type or print)
A REMPLIR PAR LE SOUMISSIONNAIRE (caractères d'imprimerie ou lettres moulées)

Vendor/Firm Name	
Address - Adresse	
Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée a signer au nom du fournisseur/ de l'entrepreneur	
Titale - Titre	
Telephone No. - N° de telephone: _____	
Facsimile No. - N° de télécopieur: _____	
Adresse courriel – Email address : _____	
Signature	Date

AMENDMENT # 2

This amendment is raised to add the following to the specification and answer/clarify the questions received:

1. Existing retaining wall along north side of lower gondola parking lot at bus sidewalk is to remain as is.
2. Q: Confirm the 1350sm value common excavation volume.
A: This number includes excavation volume mainly at the RV parking lot, side slope and other areas. Section 01 27 00 clarifies other items that required incidental excavation work such as the culvert.
3. Q: Is contractor is able to reuse excavated material on-site vs hauling away?
A: Contractor is to include for excavated materials to be hauled to a designated location outside of Banff National Park and a letter of disposal is to be submitted to the Departmental Representative
4. Q: Schedule of Quantities, Bid Item 5.3.1 and 5.4 both use the quantity of TON, confirm if this means tonne (which is 1,000kg)?
A: Yes, the value is tonne.
5. Q: Is the bid item 5.3.1 100mm GSBC for the gravel required for asphalt base for the parking lot extension only, or this quantity covers the gravel base required for the sidewalks and curbs and gutters ?
A: As mentioned in the Pavement Surfacing Assessment and Strategy report, 100mm is the maximum aggregate size for GSBC required at the parking lot extension and the new graded areas as indicated in blue hatch on drawing C15. The relevant pavement detail is shown on C19. For the sidewalks and curbs details refer to drawing L8.00 and specs section 32 16 00.
6. Clarification of seed mix and broadcast rate
 - o Broadcast seed & hydro mulch at a rate of 50 kg/ha using the seed mix in Table 2. In fall before snow cover is present, or spring prior to June 15.

Table 2. Seed Mix

Percentage (by weight)	Species
43	Hairy wild rye
34	Slender wheatgrass
21	Northern wheatgrass
2	Junegrass
1	Spike trisetum

7. Clarification to wildlife mitigations:
 - If trees to be removed are over 25cm dbh do not clear trees during the potential bat roosting window of April 1 to September 30

- In addition to the vegetation and wildlife mitigations listed, effects and mitigations regarding Species at Risk likely or possibly present at the project site are:

Species	Presence at Project Site	Potential Effects from Project	Mitigations
Bank Swallow Barn Swallow	Unknown/Possible	Visual/auditory disturbance; nest destruction	Maintain work within existing parking lot footprint; if nests are identified in project area appropriate buffer distances and requirements will be developed in consultation with ESO and PCA Wildlife staff
Little Brown Myotis	Unknown/Possible	Roosting habitat destruction	If tree removal is required within the bat roosting window (April 1 – October 1) for large diameter trees (>25cm DBH), a qualified biologist must complete an inspection for bat presence within two weeks prior to tree removal

All other terms, clauses and conditions remain unchanged.

Toutes les autres modalités, clauses et conditions demeurent les mêmes.

Signed copy of this amendment should accompany each tender. If your tender has already been submitted please sign and fax the amendment along with any revisions to tender price, to this office before the close of Tender.

Fax: 1-403-762-5057.