

Project: Cyprus Lake Campground Renewal The Head of Trails
Visitor Reception and Washroom Building

Owner: Parks Canada

Distribution:	<input checked="" type="checkbox"/>	Owner	<input type="checkbox"/>	Resident Engineer	<input type="checkbox"/>	Other
	<input checked="" type="checkbox"/>	Bidders	<input type="checkbox"/>	File		

Addendum

To All Bidders of Record:

1. General

- 1.1 This Addendum is issued prior to Tender closing to provide for certain revisions as noted herein.
- 1.2 All such revisions will become part of the Work and the effects shall be included in the Tender Price.
- 1.3 All work shall be performed in accordance with the Contract Documents.

Acknowledgement

All other Terms and Conditions remain unchanged.

Name of Firm: _____

<p>AECOM </p> <p>_____ <i>Authorized Signature:</i></p>	<p>Rick Bogaert</p> <p>_____ <i>Printed Name:</i></p>	<p>August 30, 2018</p> <p>_____ <i>Date:</i></p>
--	---	--

2. Drawings

- 1. L4 Planting Plan being re issued.

3. Specifications

- 1. Spec section 32 92 19 Seeding is being issued for Pollinator seeding.
- 2. Spec section 32 12 16 Asphalt Paving for Parking Lots and Driveways needs to be removed from the specifications.

3. Three test pits were dug while we were on site at the Pre-Bid meeting. Test pit 1 south side of the proposed building, bedrock was discovered at approximate 300 mm below existing grade. Test pit 2 north side of the proposed building, bedrock was discovered at approximate 450 mm below existing grade. Test pit 3 east of the proposed building, bedrock was discovered at approximate 600 mm below existing grade.