

**Part 1            General**

**1.1                REFERENCES**

- .1        The latest adopted version of:
  - .1        Canadian Standards Association (CSA International)
    - .1        CSA C22.2 No. 45, 65 and 182.1.
    - .2        CSA C22.2 No. 41, Grounding and Bonding Equipment.

**1.2                CERTIFICATES**

- .1        Obtain inspection certificate of compliance covering high voltage stress coning from inspection authority and include it with maintenance manuals.

**Part 2            Products**

**2.1                CONNECTORS AND TERMINATIONS**

- .1        Copper compression connectors to CSA C22.2 No. 45, 65 and 182.1 as required sized for conductors.

**Part 3            Execution**

**3.1                INSTALLATION**

- .1        Install stress cones, terminations, and splices in accordance with manufacturer's instructions.
- .2        Bond and ground as required to CSA C22.2 No. 41.

**END OF SECTION**