



## RETURN BIDS TO:

## RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government  
Services Canada/Réception des soumissions Travaux  
publics et Services gouvernementaux Canada

1713 Bedford Row

Halifax, N.S./Halifax, (N.É.)

Halifax

Nova Scotia

B3J 1T3

Bid Fax: (902) 496-5016

## SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise  
indicated, all other terms and conditions of the Solicitation  
remain the same.

Ce document est par la présente révisé; sauf indication contraire,  
les modalités de l'invitation demeurent les mêmes.

### Comments - Commentaires

### Vendor/Firm Name and Address

Raison sociale et adresse du  
fournisseur/de l'entrepreneur

### Issuing Office - Bureau de distribution

Atlantic Region Acquisitions/Région de l'Atlantique  
Acquisitions

1713 Bedford Row

Halifax, N.S./Halifax, (N.É.)

Halifax

Nova Scot

B3J 1T3

<b>Title - Sujet</b> Sea Container	
<b>Solicitation No. - N° de l'invitation</b> W7707-196307/A	<b>Amendment No. - N° modif.</b> 007
<b>Client Reference No. - N° de référence du client</b> W7707-19-6307	<b>Date</b> 2018-09-06
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$HAL-121-5754	
<b>File No. - N° de dossier</b> HAL-8-80003 (121)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2018-09-11</b>	<b>Time Zone</b> <b>Fuseau horaire</b> Atlantic Daylight Saving Time ADT
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Russell (HAL), Alex	<b>Buyer Id - Id de l'acheteur</b> hal121
<b>Telephone No. - N° de téléphone</b> (902) 401-8180 ( )	<b>FAX No. - N° de FAX</b> (902) 496-5016
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b>	

Instructions: See Herein

Instructions: Voir aux présentes

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

**Amendment 007 is raised for the following:**

**Question 1**

In reference to previous amendment (005), answer 2a states the Russestoll receptacle must be rated 400amp, for a container, this is very high. The amperage for an entire vessel is 400amp. Please confirm if this is correct.

**Answer**

2a is correct, a 400 amp rated receptacle is required.

**Question 2**

In reference to previous amendment (005), answer 2b, what is required here is a panel 120/208V – 3 phase, not as indicated. Please confirm.

**Answer**

Answer 2b is correct, 240/120 in a Delta configuration, not a 208/120 Y configuration output.

**Question 3**

In reference to previous amendment (005), answer 2d calls for 60Amp, 440V, 3 phase breaker. According to code, a 90Amp is required for a 50 KVA transformer.

**Answer**

Answer 2d called for 60Amp, 440V, 3 phase breaker. As the electrical code must be complied with thus any equipment provided must adhere to code. Therefore provide an appropriate 90Amp breaker.

**Question 4**

Can you please specify the marine paneling you are requesting? The minimum joiner panel we can get is 1". Please confirm.

**Answer**

A 1" joiner panel is acceptable.

***All other terms and conditions remain the same.***