



NOTES:
1. SITE SERVICES SHOWN FOR REFERENCE ONLY. ALL SERVICE LOCATIONS ARE TO BE CONFIRMED PRIOR TO CONSTRUCTION
2. IT WAS NOTED DURING THE VIDEO INSPECTIONS THAT DUE TO RELATIVELY FLAT PIPE RUNS THERE IS SEDIMENT GATHERING IN THE PIPE
3. LINE WORK FOR THE EXISTING BUILDINGS AND STRUCTURES WAS OBTAINED FROM PWGCS DRAWINGS PROVIDED TO US.
4. SURVEY COMPLETED ON JANUARY 16, 2018. PEI MONUMENT # 2977 WAS USED FOR CONTROL IN NAD83
EASTING: 457702.590
NORTHING: 700429.530
ELEVATION: 14.07
SURVEY INFORMATION WAS CONVERTED FROM NAD83 TO NAD83 UTM ZONE 20, AND ELEVATIONS WERE ADJUSTED BASED ON PUBLISHED CHART DATUM (+1.066m).

- LEGEND
- EDGE OF PAVEMENT
 - EXISTING BUILDING
 - ARMOR STONE TOE
 - EXISTING GUIDE RAIL
 - EXISTING SANITARY SEWER
 - EXISTING STORM SEWER
 - PROPERTY LINE
 - COORDINATE GRID MARKER
 - EXISTING GROUND ELEVATION
 - BH 18-02 GEOTECHNICAL BOREHOLE
 - CB 6 CATCH BASIN
 - MH MANHOLE
 - FIRE HYDRANT
 - GATE VALVE
 - LIGHT



GEMTEC
CONSULTING ENGINEERS
AND SCIENTISTS



1	ISSUED FOR TENDER	AUG 16 2018
revisions		date
project		project

**MARSHALLING YARD
SOURIS, PEI**

drawing destin

EXISTING CONDITIONS

designed JK	conçu
date FEB 2018	
drawn MN	dessiné
date FEB 2018	
approved	approuvé
date	
Tender 2018-08-27	Submission
PWGSC Project Manager	Administrateur de projets TPSCC
project number	no. du projet
R.090692.001	
drawing no.	no. du dessin
C1	