



TENDER AMENDMENT

RETURN BIDS TO:

Parks Canada Agency
Mailroom
30 Victoria street
Gatineau, Quebec, J8X 0B3

The referenced document is hereby amended: unless otherwise indicated, all other terms and conditions of the contract remain the same.

Issuing Office:

Parks Canada Agency
Mailroom
30 Victoria street
Gatineau, Quebec, J8X 0B3

MODIFICATION D'APPEL D'OFFRES

RETOURNER LES SOUMISSIONS Á :

Agence Parcs Canada
Salle du courrier
30 rue Victoria
Gatineau (Quebec) J8X 0B3

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Bureau de distribution :

Agence Parcs Canada
Salle du courrier
30 rue Victoria
Gatineau (Quebec) J8X 0B3

Title: Head of Trails Renewal, Cyprus Lake, Bruce Peninsula National Park		
Solicitation No.: / N° de l'invitation : 5P201-18-0132/A	Amendment No.: / N° de modification de l'invitation : 003	Date: September 12, 2018 Date : 12 septembre 2018
GETS Reference No.: / N° de référence de SEAG : PW-18-00838974		
Solicitation Closes: / L'invitation prend fin :		
At: 02:00 PM	On: September 20, 2018	Time Zone: Eastern Daylight Time (EDT)
Á : 14h00	Le : 20 septembre 2018	Fuseau horaire : Heure avancée de l'est (HAE)
Address Inquiries to: / Adresser toute demande de renseignements à : Christian Kagabo		
Telephone No.: / N° de téléphone : 819-420-5109	Fax No.: / N° de télécopieur : 819-420-9626	Email Address: / Courriel : Christianjoel.Kagabo@pc.gc.ca
TO BE COMPLETED BY THE BIDDER (type or print) À ÊTRE COMPLÉTER PAR LE SOUMISSIONNAIRE (taper ou écrire en caractères d'imprimerie)		
Vendor/Firm Name – Nom du fournisseur/de l'entrepreneur		
Address - Adresse		
Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur		
Title - Titre		
Signature		Date



AMENDMENT 003

This amendment is being raised to :

- a. Extend the solicitation period and;
- b. Respond to questions

for solicitation 5P201-18-0132/A.

A. SOLICITATION PERIOD.

1. DELETE:

Solicitation Closes: / L'invitation prend fin :

At: 02:00 PM **On:** September 13, 2018

À : 14h00 **Le :** 13 septembre 2018

2. INSERT:

Solicitation Closes: / L'invitation prend fin :

At: 02:00 PM **On:** September 20, 2018

À : 14h00 **Le :** 20 septembre 2018

B. QUESTIONS AND ANSWERS.

Question #1 Tender form asks for Concrete Paving with welded wire mesh. We couldn't find any detail/size for wire mesh in the drawings or specifications. Also please advise on wire mesh requirement for building slab on grade.

Answer #1 No welded wire mesh required in concrete paving.

Question #2 After reviewing the specifications for this project in division 4, we noticed that Blok Lok is listed for Reinforcing wire and also control joint and through wall venting. Could BL507, BL407, BLT9As anchors be considered where the Fero anchor systems are specified?

Answer #2 Code compliant alternate masonry ties are acceptable. Slotted masonry ties are not acceptable.

All other terms and conditions remain the same.