



ADDENDUM #1

Solicitation Number: 18-1177

Title: Building 140 Roof Replacement (18-1177)

Date: September 19th, 2018

The following supplements and/or supersedes the Invitation to Tender documents issued on September 6th, 2018. This addendum forms part of the contract documents and is to be read, interpreted, and coordinated with all other parts. Any change to the cost of the work as a result of this addendum is to be included in the price proposal. The following revisions supersede the information contained in the original Invitation to Tender Package for the above-mentioned project to the extent referenced and shall become part thereof.

1. At "INVITATION TO TENDER" Solicitation Closes:

DELETE:

Thursday, September 20, 2018

INSERT:

Tuesday, September, 25th, 2018

2. At "BID AND ACCEPTANCE FORM", Bid Closing Time:

DELETE:

Thursday, September 20th, 2018

INSERT:

Tuesday, September, 25th, 2018

QUESTIONS AND ANSWERS (Q & A)

Q 1. The specifications call for 24 ga prefinished steel – this is very uncommon for this style of roof(double standing seam), at each transverse seam, the buildup in thickness will make seaming correctly impossible. Could the material be changed to 26ga prefinished steel?

- A 1.
1. Refer to Drawing A1 - Specifications, Prefinished Metal Roofing, Prefinished Sheet Steel: Delete bullet point reading : "Gauge: Minimum 24ga. (0.61mm or 0.024" thick)." Add new bullet point to read: "Gauge: Minimum 26ga. (0.53mm or 0.021" thick)."
 2. Refer to Drawing A1 - Specifications, Prefinished Metal Roofing, Flashing and Trim: Delete bullet point reading : "min 24ga. (0.61 mm or 0.024" thick). All flashing and trim to have folded edges where exposed." Add new bullet point to read: "min 26ga. (0.53 mm or 0.021" thick). All flashing and trim to have folded edges where exposed."



Agriculture and
Agri-Food Canada

Agriculture et
Agroalimentaire Canada

Q 2. Instead of 2400mm long staggered panels, could seamless panels from eave to ridge be used?

A 2. Panel length and staggering installation requirements to remain as specified.

ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME

End of Addendum #1