



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Public Works and Government Services Canada
ATB Place North Tower
10025 Jasper Ave./10025 ave. Jasper
5th floor/5e étage
Edmonton
Alberta
T5J 1S6
Bid Fax: (780) 497-3510

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

**Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur**

Issuing Office - Bureau de distribution
Public Works and Government Services Canada
ATB Place North Tower
10025 Jasper Ave./10025 ave Jasper
5th floor/5e étage
Edmonton
Alberta
T5J 1S6

Title - Sujet Conduit Replacement Drumheller Inst	
Solicitation No. - N° de l'invitation EP922-190895/A	Amendment No. - N° modif. 005
Client Reference No. - N° de référence du client CSC	Date 2018-09-19
GETS Reference No. - N° de référence de SEAG PW-\$PWU-201-11430	
File No. - N° de dossier PWU-8-41093 (201)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2018-10-03	Time Zone Fuseau horaire Mountain Daylight Saving Time MDT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Ho (RPC), Hector	Buyer Id - Id de l'acheteur pww201
Telephone No. - N° de téléphone (780) 901-0989 ()	FAX No. - N° de FAX (780) 497-3510
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation
EP922-190895/A

Amd. No. - N° de la modif.
005

Buyer ID - Id de l'acheteur
pwu201

Client Ref. No. - N° de réf. du client
CSC

File No. - N° du dossier
PWU-8-41093

CCC No./N° CCC - FMS No./N° VME

Veillez consulter la version anglaise de la modification

ADDENDUM

Project Title:	Addendum No:
DI Conduit Replacement & Expansion	4
Project Location:	Project Number:
CSC Drumheller Institution, Drumheller, Alberta	R.078549.001
Consultant's Name:	Date:
DGH Engineering Ltd.	September 19, 2018

The following changes in the bid documents are effective immediately.
This addendum will form part of the contract documents.

General Comments

- 1 This Addendum addresses 3 additional bidders' questions from the Mandatory Construction Tender Site Walk conducted on September 5th, 2018.

Q1. Is RGS the conduit type for both the breeze-way and the crawl spaces.

A1. Correct, rigid galvanized steel conduit shall be provided for both the breeze-way and the crawlspaces.

Q2. Is there any reinforcement in the duct banks.

A2. Cast-in-place duct banks do not require reinforcement. Pre-cast duct banks shall be reinforced as per the following:

Specifications Section 33 65 73 Concrete-Encased Duct Banks & Manholes, Part 2.4 Precast Concrete Manholes, Pull Boxes & Duct Banks to be amended as follows:

-Replace Clause 2.4.5 with:

.5 Reinforcement of precast concrete to ASTM A1064/A1064M – 17 or CAN/CSA G30.18-09 (R2014).

Q3. The height of the perimeter fence.

A3. As per the CSC Technical Criteria 2015, SP-2 4.2.4.2.1, the height of the perimeter fence is 3.6 m.

Drawings

Specifications