



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
1713 Bedford Row
Halifax, N.S./Halifax, (N.É.)
Halifax
Nova Scotia
B3J 1T3
Bid Fax: (902) 496-5016

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Atlantic Region Acquisitions/Région de l'Atlantique
Acquisitions
1713 Bedford Row
Halifax, N.S./Halifax, (N.É.)
Halifax
Nova Scot
B3J 1T3

Title - Sujet CCGS EG - Main Engine Pre-Heat Sys.	
Solicitation No. - N° de l'invitation F5561-180652/B	Amendment No. - N° modif. 002
Client Reference No. - N° de référence du client F5561-18-0652	Date 2018-09-20
GETS Reference No. - N° de référence de SEAG PW-\$HAL-304-10501	
File No. - N° de dossier HAL-8-81106 (304)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2018-09-26	Time Zone Fuseau horaire Atlantic Daylight Saving Time ADT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Bowman, Paul	Buyer Id - Id de l'acheteur hal304
Telephone No. - N° de téléphone (902) 802-8304 ()	FAX No. - N° de FAX (902) 496-5016
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation Amendment 002

This amendment is issued to extend the solicitation period and post questions and answers.

Questions and Answers:

Q1: Would a pre-heater unit with an overall depth of 405mm be acceptable if all other dimensions are met?

A1: CG has re-evaluated its maximum allowable dimensions to the following to allow bidders greater flexibility.

Overall Width: 1000mm

Overall Depth: 425mm

Overall height: 750mm

(1000mm W x 425mm D x 750mm H)

Q2: CG has stated it requires a pre-heat unit capable of maintaining a jacket water pre-heat temperature of 55 degrees C, is a unit capable of maintaining a jacket water pre-heat temperature of 50 degrees C acceptable?

A2: CG will accept a pre-heater unit capable of maintaining a jacket water pre-heat temperature between 50-55 degrees C.

Solicitation closing date extended to September 26, 2018