



**RETURN BIDS TO:  
 RETOURNER LES SOUMISSIONS A:  
 Bid Receiving/Réception des  
 sousmissions**

**RCMP / GRC  
 Procurement & Contracting services  
 c/o Commissionaires, F Division  
 6101 Dewdney Avenue  
 Regina, SK S4P 3K7**

**Facsimile Number for Amendments:  
 (306) 780-5232**

**SOLICITATION AMENDMENT  
 MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les memes.

**Comments - Commentaries**

**Vendor/Firm Name and Address  
 Raison sociale et adresse du  
 fournisseur/de l'entrepreneur**

**Facsimile No. - No de télécopieur:**

**Telephone No. - no de téléphone:**

|   |  |
|---|--|
| Title-Sujet Construct, Deliver and Install Mobile Trailers in Brochet and South Indian Lake, MB   |  |
| Solicitation No. - No. de l'invitation<br>M5000-19-1958/A   | Date<br>21 September 2018              |
| Amendment No. - No modif.<br>01   |  |
| Client Reference No. - No. De Référence du Client<br>M5000-19-1958/A  |  |
| GETS Reference No. - No. de Référence de SEAG<br>PW-18-00842946   |  |
| Solicitation Closes -L'invitation prend fin<br>at - à 2 :00 pm <b>Central Standard Time</b><br>on - le 27 September 2018  |  |
| F.O.B. - F.A.B.<br>Destination  |  |
| Address Enquiries to: - Adresser toutes questions à:<br>Teresa Hengen, Contracting Officer  |  |
| Telephone No. - No de téléphone<br>(639) 625-3449   | Fax No. - N° de FAX:<br>(306) 780-5232 |
| Destination of Goods, Services, and Construction:<br>Destinations des biens, services et construction:<br>Royal Canadian Mounted Police<br>Brochet Manitoba and South Indian Lake, Manitoba |  |
| This document does not contain a <b>PERSONNEL SECURITY Clearance requirements</b>   |  |
| Delivery Required - Livraison exigée:<br>See Herein Voir aux présentes  | Delivery Offered - Livraison proposée  |
| Name and title of person authorized to sign on behalf of Vendor/Firm<br>Nom et titre de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur                              |  |



This amendment is raised to respond to a question raised during the solicitation period:

Delete:

**Solicitation Closes -L'invitation prend fin**

at - à 2:00 p.m. Heure normale du centre

on - le 27 September 2018

Insert:

**Solicitation Closes -L'invitation prend fin**

at - à 2:00 p.m. Heure normale du centre

on - le 28 September 2018

Q1) According to our transportation company the bridge into Brochet will not accommodate a 16ft wide building. Would it be acceptable to change the size to a 14ft x 58ft thereby maintaining the square footage?

A) This is acceptable. Width is restricted to 14 feet (4.27 metres) on the Cochrane River Bridge between the Brochet junction and Brochet. Please refer to provincial website below (near bottom of the page).

Q2) In conversation with flooring supplier, it seems the only flooring that will meet all of the Performance Requirements as listed would be a Quartz Tile. Specifically, it's the flame spread and smoke development requirements that are not available in a sheet vinyl product. Can these requirements be adjusted to suit a sheet vinyl product or would the Quartz Tile be preferred?

A) Flooring to be as per specifications. At least two products that meet the specifications are readily available.

Q3) Would steel preformed pre-finished cladding be acceptable for the exterior finish? Cost would be reduced, potential damage mitigated and future panel availability and replacement easier.

A: This is acceptable.

Q4) Would steel preformed pre-finished skirting panels be acceptable? See above

A) Yes, this is acceptable.

Q5) Would a vinyl clad or painted gypsum board ceiling be acceptable? Could also be installed with square edges, battens as per tile requirements, including over OSB substrate.

A) Acceptable to Consultant

Q6) What type of baseboards would be acceptable?

A) Vinyl that matches the vertical 'batten' mouldings for the partitions is acceptable, as is MDF base.

Q7) Due the nature of shift work often required by law enforcement, sound insulation is sometimes included in the bedroom interior partitions, would this be a requirement?

A) This is not a requirement.

Q8) In the Summary of Work, it is indicated the Electrical Hook-up is specifically excluded from this contract. How should the electrical system be terminated within/on the building? Should a pre-wired



mast and meter socket be included for the connection by others, or should the electrical panel be the termination point?

A) Terminate at electrical panel.

Q9) Are Drawings or conceptual Drawings available?

A) No, this project is 'design-build' in its approach; provide shop drawings for review.

Q10) I do not see any layout drawing or summary of work that depicts the type and total number of mobile trailers required?

A) One trailer for delivery to Brochet. One trailer for delivery to South Indian Lake.

Q11) Building code requires the installation of an HRV system for this building, but is not referenced in the Specifications. Is there a specific model requirement or is the proponent to supply/install an appropriately designed system?

A) Proponent to supply/install an appropriately designed system for the size of the mobile home.

Q12) Request for Equals: Products proposed by Jones Goodridge are acceptable with the exception of the 40 Gallon Propane Fired Water Heater. All water heaters must be direct vent, and the one included is not direct vent. Water heater must be certified for use in mobile home installation.

Spec. Section D2010:

| Clause | Specified Product  | Proposed Product   |
|--------|--|--|
| 2.2    | Non-Specified 40 Gallon Propane Fired Water Heaters              | Bradford White <a href="#">RG240S6X</a> Propane Fired Water Heaters  |
| 2.3.1  | Non-Specified Stainless-Steel Double Bowl Kitchen Sinks          | Kindred <a href="#">QDL2031/7</a> Stainless Steel Double Bowl Kitchen Sinks  |
|        | Non-Specified Kitchen Faucets and Trim                           | Delta Faucets <a href="#">136-DST</a> Kitchen Faucets and Trim   |
| 2.3.2  | Non-Specified Oval Drop in Lavatories                            | Contrac Catalina <a href="#">4140BGW</a> Drop in Lavatories  |
|        | Non-Specified Lavatory Faucets and Trim                          | Delta Faucets <a href="#">536-DST</a> Lavatory Faucets and Trim  |
| 2.4    | Non-Specified Acrylic or Fiberglass Combination Bath tub/Showers | Maax <a href="#">107001-R/L-000-001</a> Acrylic Bath tub/Showers   |
|        | Non-Specified Telephone Shower Head and Trim                     | Delta <a href="#">T14438-SSLHD</a> ; <a href="#">56613-SS</a> ; <a href="#">R10000-UNWS</a> Telephone Shower Head and Trim |
| 2.5    | Non-Specified Floor-mount syphon jet water closets               | Contrac Cody <a href="#">4722BEV</a> ; <a href="#">4721BFV</a> Water Closets   |
|        | Non-Specified Water Closet Seat with Cover                       | Bemis <a href="#">7300SLEC</a> Water Closet Seats  |

ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME



**Royal Canadian Mounted Police**  
**Gendarmerie royale du Canada**

---

Government  
of Canada

Gouvernement  
du Canada

Solicitation No./No de l'invitation: M5000-19-1958/A  
Amendment No./ No modif: 001

---