

Marginal Wharf Reconstruction
Foxtrap, NL
P/N: 721924

Page 1
2018-03-31

PART 1 - GENERAL

- 1.1 DESCRIPTION .1 This section specifies the requirements for supply and installation of mooring devices as follows:
.1 Supply and installation of Type "B1" mooring cleats.
- 1.2 RELATED WORK .1 Section 03 10 00 - Concrete Forming and Accessories.
.2 Section 03 20 00 - Concrete Reinforcing.
.3 Section 03 30 00 - Cast-in-Place Concrete.
- 1.3 MEASUREMENT FOR PAYMENT .1 Type B1 Mooring Cleats - wharf: The supply and installation of Type "B1" mooring cleats, including reinforced concrete pedestal, will be measured by the unit secured in place. Contractor to provide all concrete, reinforcing steel, anchor bolts, nuts, washers, grout, fastenings, paint, plant, equipment, and labour.

PART 2 - PRODUCTS

- 2.1 MATERIALS .1 Mooring Devices:
.1 Mooring Cleats Type "B1": galvanized cast iron cleats, 36.2 kg weight as dimensioned on the attached drawing.
.2 Anchor Bolts and Nuts: to ASTM A307, galvanized.
.3 Non-Shrink Grout: pre-mixed compound of non-metallic aggregate and plasticizing agents, capable of developing minimum compressive strength of 50 MPa at 28 days.
.4 Galvanizing: to CSA G164, minimum zinc coating 610 g/m².
.5 Welding: to CSA W59.
.6 Sealer: to Section 07 92 10.
.7 Concrete: to Section 03 30 00.

Marginal Wharf Reconstruction
Foxtrap, NL
P/N: 721924

Page 2
2018-03-31

.8 Concrete Reinforcement: to CSA G30.12M,
Grade 400.

- 2.2 SHOP DRAWINGS .1 Submit fabricator's shop drawings on cleats
in accordance with Section 01 33 00 -
Submittal Procedures.

PART 3 - EXECUTION

- 3.1 INSTALLATION .1 Mooring Cleats - Type "B1":
.1 Install concrete cleat block for Type
"B1" cleats as per attached drawings.
.2 Install concrete cleat blocks
monolithically with deck.
.3 Secure cleats with 25 mm diameter anchor
bolts of lengths required complete with
associated nuts and washers.
.4 After cleat installation is complete,
bolt holes in cleats to be filled with
approved waterproofing compound.

- 3.2 GROUT .1 Set all mooring cleats at locations and
elevations indicated or as directed by the
Departmental Representative. Grout under
base of cleat using a non-shrink,
non-metallic type of grout after tightening
of anchor bolts or positioning wedges. Grout
must be approved by Departmental
Representative. Fill anchor bolt holes with
approved sealer. Ensure that temperatures of
foundation, air, base and grout are within
range specified by grout manufacturers.
- .2 Do not grout until approval given by
Departmental Representative.