



**RETURN BIDS TO:**

**RETOURNER LES SOUMISSIONS À:**

Public Works and Government Services Canada  
ATB Place North Tower  
10025 Jasper Ave./10025 ave. Jaspe  
5th floor/5e étage  
Edmonton  
Alberta  
T5J 1S6  
Bid Fax: (780) 497-3510

**SOLICITATION AMENDMENT  
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

**Comments - Commentaires**

**Vendor/Firm Name and Address**  
**Raison sociale et adresse du**  
**fournisseur/de l'entrepreneur**

**Issuing Office - Bureau de distribution**  
Public Works and Government Services Canada  
ATB Place North Tower  
10025 Jasper Ave./10025 ave Jasper  
5th floor/5e étage  
Edmonton  
Alberta  
T5J 1S6

<b>Title - Sujet</b> Alpine Stables Reconstruction	
<b>Solicitation No. - N° de l'invitation</b> EP922-191264/A	<b>Amendment No. - N° modif.</b> 004
<b>Client Reference No. - N° de référence du client</b> Parks Canada	<b>Date</b> 2018-10-02
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWU-004-11447	
<b>File No. - N° de dossier</b> PWU-8-41106 (004)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2018-10-04</b>	<b>Time Zone</b> <b>Fuseau horaire</b> Mountain Daylight Saving Time MDT
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Espedido, Karielen K.	<b>Buyer Id - Id de l'acheteur</b> pwu004
<b>Telephone No. - N° de téléphone</b> (780) 231-4719 ( )	<b>FAX No. - N° de FAX</b> (780) 497-3510
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b> Parks Canada (PC) Waterton Lakes National Park Waterton, AB (See Herein)	

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

Solicitation No. - N° de l'invitation  
EP922-191264/A

Amd. No. - N° de la modif.  
004

Buyer ID - Id de l'acheteur  
pwu004

Client Ref. No. - N° de réf. du client  
Parks Canada

File No. - N° du dossier  
PWU-8-41106

CCC No./N° CCC - FMS No./N° VME

---

This amendment has been raised with the following changes:

**AMENDMENT #004:**

**ADDENDUM #003:**

The following changes to the tender documents are effective immediately and will form part of the contract documents:

**BIDDER QUESTIONS & ANSWERS**

**Q1:** We noticed on drawing details 8/A2.1 and 5/A2.2 that 100mm concrete faced xps rigid insulation is noted. These drawings show this kind of insulation extending the full height of the frost wall. There was no mention of rigid insulation questions or answers in the three addenda issued.

Please clarify if we are required by the energy or building code to provide a full height XPS concrete faced frost wall coverage. Otherwise please confirm with us if we can only use the concrete faced XPS rigid insulation product for the above grade exposure height. Then the remainder of the wall height below grade can be non concrete faced xps rigid insulation.

**A1:** The insulation is required by structural rather than the energy code or the building code.

"Otherwise please confirm with us if we can only use the concrete faced XPS rigid insulation product for the above grade exposure height." **Yes, this is above grade.** "Then the remainder of the wall height below grade can be non concrete faced xps rigid insulation". **Yes.**

**END OF AMENDMENT**