

The following changes in the bid documents are effective immediately. This addendum will form part of the contract documents.

DIVISION 2 – EXISTING CONDITIONS

SECTION: 02 41 16.1 - STRUCTURE DEMOLITION

Part 1 – GENERAL

Delete Clause 1.9.2.4

DIVISION 31 – EARTHWORK

SECTION: 31 05 16 - AGGREGATE MATERIALS

Part 2 – PRODUCTS

2.1 MATERIALS

.10 Delete in its entirety

Add of the following:

.10 Stone for Under Layer (200-300kg)

- .1 Under layer and Lower Layer refer to the stone placed below the middle layer armour stone.
- .2 Size range for Under Layer (200-300kg) of 480 mm to 600 mm diameter.
- .3 Alternative size: match material specifications for toe berm

.11 Armour stone shall be clean, hard, durable, angular non-friable limestone or igneous rock free from cracks, seams, chert or other defects which may impair durability. The least dimension of each armour stone shall be not less than 1/3 of its greatest dimension.

Part 3 – EXECUTION

Add clause 3.2.7 and 3.2.8 as follows:

3.2.7 The Departmental Representative will establish a top elevation of the lower layer after a review of the quarries supplying armour stone. Lower layer stone is to be placed to this elevation. Armour stone for middle layer and top layer, satisfying the material specifications shall be placed on the approved lower layer surface.

3.2.8 The alternative size material for the lower layer may be placed by end dumping and shaping to the specified profile. The layer thickness shall be 600 mm with a tolerance of 100 mm.

