



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

**Parks Canada Agency
1869 Upper Water Street,
Suite AH 201
Halifax, Nova Scotia
B3J 1S9**

SOLICITATION AMENDMENT

MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaries

Vendor/Firm Name and Address
Raison sociale et adresse du fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

**Parks Canada Agency
1869 Upper Water Street,
Suite AH 201
Halifax, Nova Scotia
B3J 1S9**

Title-Sujet Blockhouse Restoration Project, Fort George National Historic Site		
Solicitation No. - No. de l'invitation 5P201-18-0166/A		Amendment No./N° de modification de l'invitation 003
Client Ref. No. - No. de réf du client. 1504		Date: 22 October 2018
GETS Reference No. - No de reference de SEAG PW-18-00845316		
Solicitation Closes:		
at - à 14:00	on - le 30 October 2018	Time Zone - Fuseau horaire ADT - HAA
F.O.B. - F.A.B.		
Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>		
Address Inquiries to: - Adresser toute demande de renseignements à : Jaime Creaser, Jaime.Creaser@pc.gc.ca		
Telephone No. - No de téléphone (902. 426-7513		Fax No. - No de FAX: (902. 426-1775
Destination of Goods, Services, and Construction: Destinations des biens, services et construction: See Herein – Voir aux présentes		

**TO BE COMPLETED BY THE BIDDER (type or print.
À ÊTRE COMPLÉTER PAR LE SOUMISSIONNAIRE (taper ou écrire
en caractères d'imprimerie.**

Vendor/Firm Name - Nom du fournisseur/de l'entrepreneur	
Address - Adresse	
Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur	
Titale - Titre	
Telephone No. - N° de téléphone: _____	
Facsimile No. - N° de télécopieur: _____	
Signature	Date

AMENDMENT 003

This amendment is being raised to revise the specifications and to answer questions for solicitation 5P201-18-0166/A:

1. MODIFICATION TO SPECIFICATIONS

Specification section 07 46 23 Wood Siding, Subsection 2.1 Materials

INSERT: Subsection .2.2

Primer to be oil/alkyd primer conforming to MPI Painting Specification System EXT 6.2A (Specified in Section 09 91 13, paragraph 2.5.1), factory applied on all six sides of every piece. Primer shall contain the following: Water repellent, Fungicide/mildewcide; protection against ultra violet (UV) light.

2. QUESTIONS AND ANSWERS

Q27. Are we able to work 7 days a week, and can we start to work at 8:00 AM and what time in the PM can we stay.

A27. Site access and hours of work shall be coordinated with the Project Manager after award to ensure maximum time to complete the project is made available with minimum impact to the site operational requirements.

Q28. Can we operate construction equipment within the Fort George pedestrian concrete sidewalks, for transport purposes?

A28. Please refer to amendment 002.

Q29. Will parks Canada provide a staging construction area for the general Contractor?

A29. Please refer to amendment 002.

Q30. Can we allocate on site a construction office trailer?

A30. Please refer to amendment 002.

Q31. Will Parks Canada provide on-site storage space to house all the electrical fixtures that are to be removed and re-installed?

A31. On site storage is available and will be coordinated with the Project Manager after award.

Q32. In accordance with the Electrical Drawings specifically articulates that 4 new weather proof switches are to be installed to operate the existing lights in the tunnel and magazine building....can we place the 4 switches into one housing that is weather proof and install it next to the new electrical panel.

A32. This is acceptable subject to Parks Canada review of shop drawings, final arrangement and details. Electrical equipment is not permitted to unduly restrict corridor width or door swing.

Q33. Our Suppliers for the Red Cedar Siding have informed us that the length of each piece of siding will be random sizes and cannot guaranty specific sizes, the supplier can provide specific sizes at a premium cost in limited sizes...please clarify how Parks Canada wants the Cedar Siding in Linear Lengths.

A33. Random lengths are acceptable. Refer to Section 07 46 23, paragraph 3.1.3.

Q34. Will Parks Canada assist the Contractors with free on-site parking?

A34. Lay-up areas and contractor parking areas to be established with the Project Manager after contract award.

Solicitation No. - N° de l'invitation
5P201-18-0166/A

Amd. No. - N° de la modif.
003

Buyer - l'acheteur
Jaime Creaser

Client Ref. No. - N° de réf. du client
1504

File Name - Nom du dossier
Blockhouse Restoration Project, Fort George National Historic Site

ALL OTHER TERMS AND CONDITONS REMAIN THE SAME.
