

Solicitation No. - N° de l'invitation
F2930-180030/A
Project No. 722878

ATT. 028

QUESTION AND ANSWER

- Q55. Anchor Wall Type B there appears to be a conflict in notes on drawing S-21. The plan view detail annotates it as "SSP Wall (SSP 1)" whereas detail 2 on the same drawing annotates it as "Steel Sheet Pile (SSP 2)." Can you please confirm that it should be "SSP Wall (SSP 1)" used for the Anchor Wall – Type B sheets?
- A55. Section 2 on Drawing S-21 (for Anchor Wall Type B) should indicate SSP 1 piling (not SSP 2).