

ATT. 029

QUESTION AND ANSWER

- Q56. The material specifications for type 2 sheet piles states a minimum length of 9.1m. Based on the drawings, approximately 225m of the Type 2 SSP wall is only 7.65m in depth, meaning the 9.1m length sheets would have a significant waste cut off. Can the contractor utilise shorter sheets for these locations?
- A56. Provide 9.1 m long sheets for Steel Sheet Pile SSP 2 per Section 31 62 16.13 and Drawing S-09. The toe of SSP2 on Section 17, Drawing S-13 shall be Elevation -7.1 m (IGLD). The toe of SSP2 on the East Pier West Elevation for the same section of wall, Drawing S-16 shall be Elevation -7.1 m (IGLD).