



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS Á:

**Parks Canada Agency
Banff Field Unit
PO Box 900
216 Hawk Avenue
Banff, AB, T1L 1K2**

AMENDMENT #3 TO:

INVITATION TO TENDER

APPEL D'OFFRES

Tender To: Parks Canada Agency
We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services, and construction listed herein and on any attached sheets at the price(s) set out therefor.

Soumission aux: l'Agence Parcs Canada
Nous offrons par la présente de vendre à Sa Majesté la Reine du Chef du Canada, aux conditions énoncées ou incluses par référence dans la présente at aux annexes ci-jointes, les biens, services et construction énumérés ici et sur toute feuille ci-annexée, au(x) prix indiqué(s).

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

**Parks Canada Agency
Banff National Park
PO Box 900
Banff, AB
T1L 1K2**

Title-Sujet CAVE & BASIN BELVEDERE DECK & STRUCTURE REHABILITATION, Banff NP, Banff, AB		
Solicitation No. - No. de l'invitation 5P421-18-1074/A	Date: October 23, 2018	
GETS Reference No. - No de reference de SEAG PW-18-00845874	Client Ref. No. - No. de réf du client.	
Solicitation Closes:		
at - à 02:00 PM	on - le AMENDED TO: October 26, 2018	Time Zone - Fuseau horaire Mountain Daylight Time (MDT) - Heure avancée des Rocheuses (HAR)
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>		
Address Inquiries to: - Adresser toute demande de renseignements à : Annie Roy annie.roy@pc.gc.ca		
Telephone No. - No de téléphone 403-762-1459	Fax No. - No de FAX: 403-762-5057	
Destination of Goods, Services, and Construction: Destinations des biens, services et construction: See Herein - Voir ci-joint		

TO BE COMPLETED BY THE BIDDER (type or print)
A REMPLIR PAR LE SOUMISSIONNAIRE (caractères d'imprimerie ou lettres moulées)

Vendor/Firm Name	
Address - Adresse	
Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée a signer au nom du fournisseur/ de l'entrepreneur	
Titale - Titre	
Telephone No. - N° de telephone: _____	
Facsimile No. - N° de télécopieur: _____	
Adresse courriel - Email address : _____	
Signature	Date

AMENDMENT # 3

THE PURPOSE OF THIS AMENDMENT IS TO AMEND THE INVITATION TO TENDER THE FOLLOWING WAY:

#1. QUESTIONS AND ANSWERS

Q #1.
Are there any restrictions (time or sensitivity for structure) to using pneumatic tools to break up the concrete stairs?

A #1.
We ask that Contractor aims to schedule disruptive (noise) work at off peak hours. Light pneumatic tools are acceptable. Use with care so as not to damage the rebar or remove more than the depth shown on the drawing.

Q #2.
Specification section 034800.2.1.10 appears to indicate that the pavers will have a prism insert (which you supply).
It also specifies that these are cast into the pavers which is not likely in our time frame for this project.
It then references section 26 and describes LED lighting (034800.2.3.4) cast into the pavers.
Are either of these items required?

A #2.
Omit, does not pertain to this project.

Q #3.
Specification section 040439.1.4 references specification sections that do not exist for this project.

A#3.
See attached PDF file: "04 03 39 – Historic – Dismantling Stone Masonry.pdf – 2018-10-22" added under "Attachment" section of the Buy and Sell webpage for this project for revised spec section 04 04 39 addressing concerns of reference to part 1.4 Quality Assurance. Omit lines 1.4.1.1, and 1.4.1.2

Q #4.
Section 071600.3.5.2 indicates that this material is to be applied as indicated on drawings, it does not appear to be shown on the drawings.

A #4.
See details 2&5/A-410 for new waterproofing at new stair.

Q # 5.

Would you please clarify:

In sheet A102, its mentioned that work for North Belvedere is Not In Contract labelled with "NIC" but as referred in keynotes on the same drawing sheet and also on the plans, it seems that work like removing and replacing pavers, sloped concrete topping etc. is done for the North Belvedere as well. Because there are no lines that shows "extent of work" or any other representation.

A #5.

The North Belvedere structure is Not In Contract, and is not be included in the demolition work. Also note, that it must be protected during demolition. The work on the deck (removing. replacing pavers, sloped concrete topping, etc) surrounding the North Belvedere structure is in contract.

Q #6.

Is there a Basic Impact Analysis that was to have been included in the Tender Documents? There was one referenced.

A #6.

***No, there is no Basic Impact Analysis for this project.
Environmental procedures are included within specification section 01 35 43.***