

The following changes in the bid documents are effective immediately. This addendum will form part of the contract documents.

SECTION: 35 59 14 – MISCELLANEOUS METALS

PART 1 – GENERAL

1.4 REFERENCES

Add clause .4 as follows:

- .4 The Master Painters Institute (MPI): Exterior Structural Steel and Metal Fabrications, 07.
 - .1 EXT 5.1G, Polyurethane, Pigmented (over epoxy zinc rich primer and high build epoxy).

Part 2 – PRODUCTS

2.1 MATERIALS

- .4 Delete in its entirety

Replace with:

Paint for general steel components meeting the following requirements.

- .1 Primer: MPI EXT 5.1G, zinc rich epoxy primer. Maximum MPI E2 rating on VOC.
- .2 Epoxy: MPI EXT 5.1G, high build epoxy. Maximum MPI E2 rating on VOC.
- .3 Polyurethane: MPI EXT 5.1G, aliphatic polyurethane. Maximum MPI E2 rating on VOC. Colour traffic yellow
- .4 Surface profile for shop coating abrasive blasting to SSPC-SP10 with 3 to 4 mils surface profile.