



## RETURN BIDS TO:

## RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government  
Services Canada/Réception des soumissions Travaux  
publics et Services gouvernementaux Canada  
800 Burrard Street, Room 219  
800, rue Burrard, pièce 219  
Vancouver  
British Columbia  
V6Z 0B9  
Bid Fax: (604) 775-9381

## SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise  
indicated, all other terms and conditions of the Solicitation  
remain the same.

Ce document est par la présente révisé; sauf indication contraire,  
les modalités de l'invitation demeurent les mêmes.

### Comments - Commentaires

Vendor/Firm Name and Address  
Raison sociale et adresse du  
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution  
Public Works and Government Services Canada - Pacific  
Region  
800 Burrard Street, Room 219  
800, rue Burrard, pièce 219  
Vancouver  
British C  
V6Z 0B9

<b>Title - Sujet</b> Y-Jetty and Lang Cove Remediation	
<b>Solicitation No. - N° de l'invitation</b> EZ113-190891/B	<b>Amendment No. - N° modif.</b> 008
<b>Client Reference No. - N° de référence du client</b>	<b>Date</b> 2018-10-29
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWY-020-8440	
<b>File No. - N° de dossier</b> PWY-8-41072 (020)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2018-10-31</b>	<b>Time Zone Fuseau horaire</b> Pacific Daylight Saving Time PDT
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Ly, Ronny(PWY)	<b>Buyer Id - Id de l'acheteur</b> pwy020
<b>Telephone No. - N° de téléphone</b> (604) 318-5750 ( )	<b>FAX No. - N° de FAX</b> (604) 775-6633
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b> DND - CFB Esquimalt - Victoria, BC	

Instructions: See Herein

Instructions: Voir aux présentes

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm (type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

Solicitation No. - N° de l'invitation  
EZ113-190891/B

Amd. No. - N° de la modif.  
008

Buyer ID - Id de l'acheteur  
pwy020

Client Ref. No. - N° de réf. du client

File No. - N° du dossier

CCC No./N° CCC - FMS No./N° VME

---

See Addendum 008 below.

**ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED.**

**The following changes/clarifications in the tender documents are effective immediately.**

**This Addendum 008 will form part of the contract documents**

*This Addendum 008 is issued to provide amendment to the Specifications, and Contract Drawings as attached hereto.*

**Responses to Questions from Bidders**

Q1. Can you please confirm if the volumes provided in the pricing table include the material slough in all DUs? Our calculations have the volumes of slough material in excess of 4000m due to the high number of vertical cuts.

R1. The tender volumes presented in the Unit Price Table for completion of dredging activities do not include slough material in all DUs. Additional volume associated with anticipated slough should be evaluated/considered by the contractor at all locations where vertical dredge cuts are required (both at dredge prism boundaries where dredge offsets/vertical cuts adjacent to structures are shown and at internal Dredge Unit boundaries).

The anticipated additional slough volume should be considered in contractor's tender price for completion of other construction activities related to Tender Item #21 (Dredging) that are measured by the in-situ cubic metre such as Tender Item #23 (Offloading and Transportation), Tender Item #24 (Material Processing) and Tender Item #25 (Disposal).

Q2. Can fender piles be stored in the water if they are boom and contained?

R2. Fender piles may not be stored in the water for this project.

Q3. In Section 1.3 UXO Qualified Personnel Qualifications/Experience (Table 4), is it acceptable to check "yes" to only one of the boxes under the three qualifications scenarios and "no" to the other two without checking equivalent? Is the intent that the UXOTS must be qualified under one of the follow three pathways or demonstrate equivalency for a particular pathway if they can't check yes to any?

R3. The proposed UXO Qualified Personnel must meet all qualification and experience requirements identified in Table 4. Unexploded Explosive Ordnance (UXO) Qualified Personnel Qualifications/Experience for the bid to be considered compliant as this is a mandatory component of this RFP. To demonstrate meeting each of the qualification and experience requirements the bidder must check either Yes or Equivalent in the table provided. If Equivalent is selected the bidder must also

provide supporting documents that will be reviewed by the technical review committee to confirm equivalency of education/experience.

A Brief Summary of Experience (as indicated in Table 4) and a resume (maximum 2 pages) must be provided to demonstrate that the UXO Qualified Personnel meets the qualification and experience requirements listed in Table 4.

If a bidder does not have the qualification or experience requirements, they must select Equivalent and provide documentation to demonstrate equivalent education/experience. Failure to provide the required information will result in the bid being considered non-responsive.

#### **Changes to the Specifications**

No modifications were made to the Specifications as part of this Addendum.

#### **Changes to the Drawings**

No modifications were made to the Drawings as part of this Addendum.