



**RETURN BIDS TO:
RETOURNER LES SOUMISSIONS A:
Bid Receiving/Réception des
sousmissions**

**RCMP / GRC
Procurement & Contracting services
c/o Commissionaires, F Division
6101 Dewdney Avenue
Regina, SK S4P 3K7**

**Facsimile Number for Amendments:
(306) 780-5232**

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

**The referenced document is hereby
revised; unless otherwise indicated, all
other terms and conditions remain the
same.**

**Ce document est par la présente révisé;
sauf indication contraire, les modalités
de l'invitation demeurent les memes.**

Comments - Commentaries

**Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur**

Facsimile No. - No de télécopieur:

Telephone No. - no de téléphone:

Title-Sujet Supply and Install Rubber Flooring	
Solicitation No. - No. de l'invitation M5000-19-2893/A	Date 30 October 2018
Amendment No. - No modif. 01	
Client Reference No. - No. De Référence du Client M5000-19-2893/A	
GETS Reference No. - No. de Référence de SEAG PW-18-00847389	
Solicitation Closes -L'invitation prend fin at - à 2 :00 pm Central Standard Time on - le 02 November 2018	
F.O.B. - F.A.B. Destination	
Address Enquiries to: - Adresser toutes questions à: Teresa Hengen, Procurement Officer	
Telephone No. - No de téléphone (639) 625-3449	Fax No. - N° de FAX: (306) 780-5232
Destination of Goods, Services, and Construction: Destinations des biens, services et construction: Royal Canadian Mounted Police Academy-Depot Division 5600 11th Ave Regina, SK	
This document does not contain a PERSONNEL SECURITY Clearance requirements	
Delivery Required - Livraison exigée: See Herein Voir aux présentes	Delivery Offered - Livraison proposée
Name and title of person authorized to sign on behalf of Vendor/Firm Nom et titre de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur	



The purpose of this amendment is to:

Request for Equal accepted for rubber floor matting:
ProXL Stamina by Northwest Rubber
100% vulcanized rubber
¾ inch – 4 feet x 6 feet

Questions from onsite visit:

Q1) Slope of floor should be 2% and if the finished floor is not at this, the contractor will need to adjust the floor to meet the installation needs.

R1) The 2% slope is in place on the floor, the contractor will need to make sure the slope is maintained upon installation.

Q1) What weight of filter fabric is necessary prior to the installation of the rubber matting.

R2) A medium weight 8 ounce landscape fabric

Delete:

Solicitation Closes –L'invitation prend fin
at - à 2 :00 pm Central Standard Time
on - le 01 November 2018

Insert:

Solicitation Closes –L'invitation prend fin
at - à 2 :00 pm Central Standard Time
on - le 02 November 2018