



RETURN BIDS TO:
RETOURNER LES SOUMISSIONS Á:

Parks Canada Agency Mailroom 30 Victoria Street Gatineau, Quebec, J8X 0B3

Amendment #5

INVITATION TO TENDER
APPEL D'OFFRES

Tender To: Parks Canada Agency

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services, and construction listed herein and on any attached sheets at the price(s) set out therefor.

Soumission aux: l'Agence Parcs Canada

Nous offrons par la présente de vendre à Sa Majesté la Reine du Chef du Canada, aux conditions énoncées ou incluses par référence dans la présente aux annexes cijointes, les biens, services et construction énumérés ici et sur toute feuille ci-annexée, au(x) prix indiqué(s).

Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Parks Canada Agency Mailroom 30 Victoria Street Gatineau, Quebec, J8X 0B3

Title-Sujet		Date
Replacement of Culvert and Preliminary Ground Work Forillon National Park		31 October , 2018
5P047-18-0182A		Ref. No. – No. de réf du client.
GETS Reference No. – No de reference de SEAG PW-18-00847246		
Solicitation Closes L'invitation prend fin –	Time Zone Fuseau horaire -	
at – à 02:00 PM on – le 2018-11-06	Eastern Daylight Time (EST)	
F.O.B F.A.B. Plant-Usine: Destination: Other-Autre: Address to the state of the state		
Address Inquiries to: - Adresser toute demande de renseignements à :		
Patrick Sullivan at Patrick.Sullivan2@canada.ca Telephone No No de téléphone Fax No No de FAX:		
(819) 420-9557		
Destination of Goods, Services, and Construction: Destinations des biens, services et construction:		
See Herein		
Vendor/Firm Name and Address		
Raison sociale et adresse du fournisseur/de l'entrepreneur		
Name and title of person authorized to sign on behalf of the Vendor/Firm Nom et titre de la personne autorisée a signer au nom du fournisseur/ de l'entrepreneur		
Signature		Date







AMENDMENT #5

THE PURPOSE OF THIS AMENDMENT IS TO SHARE THE ANSWERS TO THE FOLLOWING QUESTIONS ASKED BY POTENTIAL BIDDERS

THIS ADDENDUM COMPLETES, MODIFIES OR ELIMINATES CERTAIN ELEMENTS OF THE TENDER DOCUMENTS, WHICH THE ADDENDUM REFERS TO. IT IS AN INTEGRAL PART OF THE TENDER DOCUMENTS.

Questions and Answers

- Q1. Would it be possible to delay the work completion date?
- A1. Yes, PCA accept to delay the work completion date to December 14th, 2018.
- Q2. Is there a description of the backfill/excavation volumes?
- A2. See elevations of the existing ground on the attached plan extract. The plan is in the attachments named: C01-RO-DRA-1415-10_signe
- Q3. For the temporary deviation path, is there a minimum width to respect?
- A3. The minimum width of the temporary deviation path is 3.5m.
- Q4. Will it be allowed to use the existing ATV path for the temporary deviation path?

A4. No.

- Q5. According to the plans, there is no 0 4" backfill required below the "P" elevation, could you confirm? Only the roadway works are required?
- A5. Put the infrastructure as shown in the "Typical section Culverts Installation" on the C-02 sheet along the entire section of the access road affected by works.
- Q6. Do you have information about the flow in the existing creek? Is it a permanent or intermittent creek?
- A6. It is a permanent flow stream. The upstream high water mark is estimated at approximately 121.43.







- **Q7.** Is the existing culvert a galvanized corrugated steel pipe or a reinforced concrete pipe?
- A7. It is a galvanized corrugated steel pipe.
- Q8. Can you confirm that the landscaping works are planned to be done in 2019? Do we need to integrate the slopes protection during the winter in our tender slip prices?
- A8. Yes, landscaping is planned for the 2019 spring. Yes, protection of the slopes is required for the 2018-2019 winter and must be included in bid prices.
- Q9. At section 01 51 00, it is indicated that the drinkable water alimentation is to preserve. Could you confirm there is a water pipe in this sector? If it's the case, could you provide the specifications required?
- A9. No buried water pipe or buried public utility is present in this sector. The Contractor must carry out verifications with Info-Excavation to ensure this, before starting works.
- Q10. In order to determine the backfill volumes for the temporary deflection path, we need elevations of natural ground. Can you provide us with this information?
- A10. See elevations of the existing ground on the attached plan extract. The plan is in the attachments named: C01-RO-DRA-1415-10_signe
- Q11. With the Vist-a-Wall wall to install, the deadline for the completion of work on November 23 is not possible. The production time for the shop drawings and manufacturing of the cages may be around 6 weeks. Would it be possible to delay the work completion date?
- A11. Yes, PCA accept to delay the work completion date to December 14th.

ALL OTHER TERMS AND CONDITIONS OF THE ITT REMAIN UNCHANGED.

Signed copy of this amendment should accompany each tender. If your tender has already been submitted please sign and fax the amendment along with any revisions to tender price, to this office before the close of Tender. Fax: 819-420-9626

