



## RETURN BIDS TO:

## RETOURNER LES SOUMISSIONS À:

Regional Manager/Real Property  
Contracting/PWGSC  
Ontario Region, Tendering Office  
12th Floor, 4900 Yonge Street  
Toronto, Ontario  
M2N 6A6  
Ontario

### Revision to a Request for a Standing Offer

### Révision à une demande d'offre à commandes

Departmental Individual Standing Offer (DISO)

Offre à commandes individuelle du département(OCID)

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Offer remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'offre demeurent les mêmes.

#### Comments - Commentaires

Address inquiries to the Contracting Authority at  
lauren.woodhall@pwgsc-tpsgc.gc.ca

#### Vendor/Firm Name and Address

Raison sociale et adresse du  
fournisseur/de l'entrepreneur

#### Issuing Office - Bureau de distribution

Regional Manager/Real Property  
Contracting/PWGSC  
Ontario Region, Tendering Office  
12th Floor, 4900 Yonge Street  
Toronto, Ontario  
M2N 6A6  
Ontario

<b>Title - Sujet</b> Mechanical Engineering Service	
<b>Solicitation No. - N° de l'invitation</b> EQ754-190918/A	<b>Date</b> 2018-11-01
<b>Client Reference No. - N° de référence du client</b> EQ754-190918	<b>Amendment No. - N° modif.</b> 002
<b>File No. - N° de dossier</b> PWL-8-41047 (035)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWL-035-2404	
<b>Date of Original Request for Standing Offer</b> 2018-09-26	
<b>Date de la demande de l'offre à commandes originale</b>	
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2018-11-15</b>	
<b>Time Zone</b> <b>Fuseau horaire</b> Eastern Standard Time EST	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Woodhall, Lauren	<b>Buyer Id - Id de l'acheteur</b> pwl035
<b>Telephone No. - N° de téléphone</b> (416) 512-5873 ( )	<b>FAX No. - N° de FAX</b> (416) 512-5862
<b>Delivery Required - Livraison exigée</b>	
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b> Ontario Region	
<b>Security - Sécurité</b> This revision does not change the security requirements of the Offer. Cette révision ne change pas les besoins en matière de sécurité de la présente offre.	

Instructions: See Herein

Instructions: Voir aux présentes

<b>Acknowledgement copy required</b> <b>Accusé de réception requis</b>	<b>Yes - Oui</b> <input type="checkbox"/>	<b>No - Non</b> <input type="checkbox"/>
<b>The Offeror hereby acknowledges this revision to its Offer.</b> <b>Le proposant constate, par la présente, cette révision à son offre.</b>		
<b>Signature</b>	<b>Date</b>	
Name and title of person authorized to sign on behalf of offeror. (type or print) Nom et titre de la personne autorisée à signer au nom du proposant. (taper ou écrire en caractères d'imprimerie)		
<b>For the Minister - Pour le Ministre</b>		

Solicitation No. - N° de l'invitation  
EQ754-190918/A

Amd. No. - N° de la modif.  
002

Buyer ID - Id de l'acheteur  
PWL035

Client Ref. No. - N° de réf. du client  
EQ754-190918

File No. - N° du dossier  
PWL-8-41047

CCC No./N° CCC - FMS No./N° VME

---

## **Solicitation Amendment 002**

This amendment is being raised to 1) incorporate an Extension of Time for the receipt of proposals, and 2) provide responses to Requests for Clarification.

### **1. Extension of Time**

Notice is hereby given that the closing date for the reception of proposals previously due Thursday, November 8, 2018 is extended to **14:00 hours, Thursday November 15, 2018.**

### **2. Requests for Clarification**

- Q3. Can PSPC please confirm that the Ventilation minimum requirement is accurate on page 61 of the TOR? The number is currently listed as 10 L/s.
- A3. Page 61 of the TOR provides the following statement: "10.0 L/s of outside air per person is adequate for occupant comfort".

This is not the Ventilation minimum requirement. In case a calculation for minimum ventilation rates based on ASHRAE Standard 62.1 cannot be provided, 10.0 l/s OA will be accepted as adequate.

According to RS 1.1.11 page 60:

Outdoor air (minimum) ventilation rates shall be based on the latest edition of ASHRAE Standard 62.1 - "Ventilation for Acceptable Indoor Air Quality" unless special requirements or regulations dictate otherwise.

**All other terms and conditions of the solicitation remain the same.**