

QUESTION & ANSWER

Question 9

. Please specify the final coating, if any, required for any structural steel other than the specified HSS curbs.

Answer 9

There is no specified final coating for any structural steel, only for the HSS curbs.

Question 10

Please specify the rib height and gauge of steel deck required to support the concrete deck.

Answer 10

The steel deck shall be to CSA S136 16. Rib height shall be 38 mm, steel thickness, 1.22 mm minimum with minimum section modulus at midspan of $16.9 \times 10^3 \text{mm}^3$. Steel strength shall be to ASTM A 653M -17 SS with a minimum yield strength of 230 MPa with Z275 galvanizing

Question 11

Please advise if existing jetties wooden piles to be removed and disposed do not contain creosote or some other preservative that would make it classified as hazardous waste?

Answer 11

The timber (wooden) piles, timber pile caps and laminated timber decking contain creosote.

Question 12

Are we driving the pipe piles to the design depth in the drawings or the set provided in the specifications?

Answer 12

The pipe pile are to be driven to the indicated (design) depth shown on the drawings.

Question 13

Are pipe piles cleaned out and filled with concrete or just what is remaining?

Answer 13

As shown on detail 17/7/7 on drawing MA-07, the piles are to be driven closed ended and will be concrete filled full length of pile