



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

**Parks Canada Agency
3, passage du Chien-d'Or
Québec, Qc G1R 3Z8**

AMENDMENT #2

Tender To: Parks Canada Agency
We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services, and construction listed herein and on any attached sheets at the price(s) set out therefor.

Soumission aux: l'Agence Parcs Canada
Nous offrons par la présente de vendre à Sa Majesté la Reine du Chef du Canada, aux conditions énoncées ou incluses par référence dans la présente et aux annexes ci-jointes, les biens, services et construction énumérés ici et sur toute feuille ci-annexée, au(x) prix indiqué(s).

Comments - Commentaries

Vendor/Firm Name and Address
Raison sociale et adresse du fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

**Parks Canada Agency
3, passage du Chien-d'Or
Québec, Qc G1R 3Z8**

Title-Sujet Construction of North West Trail, Rouge National Urban Park		
Solicitation No. - No. de l'invitation 5P201-18-0185/A		Date: 13 November 2018
GETS Reference No. - No de reference de SEAG PW-18-00847273		Client Ref. No. - No. de réf du client. N/A
Solicitation Closes - L'invitation prend fin :		
at - à 2:00 PM	on - le November 15th 2018	Time Zone - Fuseau horaire EST - Eastern Standard Time
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>		
Address Inquiries to: - Adresser toute demande de renseignements à : Josée Gagnon josee.gagnon@pc.gc.ca		
Telephone No. - No de téléphone 418.648.2502		Fax No. - No de FAX: 418.649.6971
Destination of Goods, Services, and Construction: Destinations des biens, services et construction: See Herein - Voir aux présentes		

TO BE COMPLETED BY THE BIDDER (type or print)
À ÊTRE COMPLÉTER PAR LE SOUMISSIONNAIRE (taper ou écrire en caractères d'imprimerie)

Vendor/Firm Name - Nom du fournisseur/de l'entrepreneur	
Address - Adresse	
Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur	
Titale - Titre	
Telephone No. - N° de téléphone: _____	
Facsimile No. - N° de télécopieur: _____	
Signature	Date

AMENDMENT #2

THE PURPOSE OF THIS AMENDMENT IS TO PROVIDE ANSWERS TO QUESTIONS ASKED BY POTENTIAL BIDDERS.

YOU MUST CONSIDER THE INFORMATION BELOW, IN THE EVALUATION OF YOUR BID.

1. QUESTIONS AND ANSWERS

Q20. For boardwalk and pergola construction, please provide additional clarification regarding the connections between beams and joists. Will brackets be required?

A20. For the boardwalks, the joists should be fastened to the beams with galvanized hurricane brackets. For the pergola, the notched joists can be fastened to the beams with 3" coated deck screws.

Q21. For boardwalk construction, please confirm the dimension of the deck boards. It is indicated they are to be rough sawn, but the dimension of 38mm x 140mm is a 'dressed' dimension. Is the required rough sawn size to be 50mm x 150mm?

A21. Correct. Please bid according to the rough sawn equivalent. So for the deck boards, the rough sawn size is 50mm x 150mm.

Q22. For the boardwalk construction, the drawings indicate framing lumber to be 'Hem-Fir', and the specifications says 'spruce pine fir'. Please clarify the lumber to be used.

A22. Both pressure treated spruce-pine-fir and hem-fir are acceptable.

Q23. Please clarify where detail 5/L-500 (trail with swale) will be applicable along the trail route. We find no reference on any of the L-300 series drawings to this detail.

A23. This trail detail may be applied as site conditions require when the trail corridor is flagged. Likely it will only be applied for the north to south length in L-315. For the purpose of bidding, assume the detail is not required as part of this contract.

Q24. Please clarify where detail 6/L-500 (bench cut trail) will be applicable along the trail route. We find no reference on any of the L-300 series drawings to this detail.

A24. Again, this is an available design that may be applied as site conditions require. Likely it will be required for some sections in L-305 and on PIN 088-1 on L-310. For the purpose of bidding, assume the detail is not required as part of this contract.

Q25. The trail cross section on details drawing L-500 indicate to 'provide additional Granular B in localized areas as necessary to increase base stability'. We are unable to determine requirements at time of bidding. Please confirm any additional excavation and granular, if required, will be additional to the contract?

A25. Correct. Any additional excavation and granular, if required, will be additional to the contract and should not be factored in at this time for the purpose of bidding.

Q26. For details 4/L-500, please clarify the total depth of clear stone required under the Granular A trail base. The detail is a little unclear.

A26. The 200mm of granular A that is detailed as the trail base, will site on either 150mm of clear stone or the 'O' Drain (150mm diameter) that is spaced every 20m.

Q27. For details 5/L-500, please clarify the total depth of clear stone required under the Granular A trail base. The detail is a little unclear.

A27. There is no clear stone required in 5/L-500. If you are referring to 9-L500 then the Granular A trail base sits on 350mm of clear stone, or every 20m where the 'O' drain is required, it sits on the 'O' drain and 200mm of clear stone.

Q28. Regarding seeding, please clarify the schedule - Does the winter wheat seed mix (9700m2) get install in December 2018? And seed Mixes 1, 2, and 3 (total area 9700m2) get installed in Spring 2019?

A28. Correct.

Q29. Regarding the Post & Board fence shown on 1-L510, the 1" x 8" White Cedar is not available. Please clarify if an alternative lumber species would be acceptable. Alternatively, we would propose using 1" x 6" White Cedar, and utilizing 4 boards instead of 3. Please clarify if that would be an acceptable alternative.

A29. 1"x6" White Cedar is an acceptable alternative, but please space accordingly to keep 3 horizontal boards.

Q30. Regarding the Overhead Pergola shown on 2L-430, the 2" x 12" White Cedar is not available. As this is a structural member, we require direction on how to bid. Please clarify if an alternative lumber species would be acceptable, or provide a design utilizing a smaller lumber size, keeping in mind that manufactures can only produce White Cedar panels up to 6" per dimension.

A30. 2" x 10" rough sawn hemlock is an acceptable alternative.

THE BID CLOSING DATE REMAINS THURSDAY THE 15TH OF NOVEMBER 2018, 2PM EST.

End of section.

ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED.

Signed copy of this amendment should accompany each tender. If your tender has already been submitted please sign and fax the amendment along with any revisions to tender price, to this office before the close of Tender.
Fax: 418 649-6971.