



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Public Works and Government Services Canada
ATB Place North Tower
10025 Jasper Ave./10025 ave. Jasper
5th floor/5e étage
Edmonton
Alberta
T5J 1S6
Bid Fax: (780) 497-3510

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada
ATB Place North Tower
10025 Jasper Ave./10025 ave Jasper
5th floor/5e étage
Edmonton
Alberta
T5J 1S6

Title - Sujet Waterton Alpine Stables Building	
Solicitation No. - N° de l'invitation EP922-191669/A	Amendment No. - N° modif. 001
Client Reference No. - N° de référence du client PC	Date 2018-11-14
GETS Reference No. - N° de référence de SEAG PW-\$PWU-066-11481	
File No. - N° de dossier PWU-8-41142 (066)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2018-12-04	Time Zone Fuseau horaire Mountain Standard Time MST
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Lee, Mony	Buyer Id - Id de l'acheteur pwu066
Telephone No. - N° de téléphone (780) 224-6675 ()	FAX No. - N° de FAX (780) 497-3510
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation
EP922-191669/A

Amd. No. - N° de la modif.
001

Buyer ID - Id de l'acheteur
pwu066

Client Ref. No. - N° de réf. du client
PCA EP922-191669

File No. - N° du dossier
PWU-8-41142

CCC No./N° CCC - FMS No./N° VME

SOLICITATON AMENDMENT No. 001

See attached Addendum 002.

All other terms and conditions of the Invitation to Tender remain unchanged.

Part 1 General

- .1 This addendum consists of three (3) pages plus the following list of drawings:

No.	Drawing Title	Issue Date
E1	Site Plan and Single Line Diagram	22 October 2018
E2	Alpine Cottage and Bunk House Crawlspace Plan – Electrical and Riser Diagram	22 October 2018

1.2 CHANGES TO THE PROJECT MANUAL

.1 SECTION 01 11 00 – SUMMARY OF WORK

- .1 **Add** Item 1.1.1.1 Ready-to-move (RTM) buildings to be installed by April 1, 2019.
- .2 **Revise** Item 1.5.3.1 "*Building Foundations*, Saddling Barn, Boarding Barn, and site work including weather shelter, fences and corrals, landscaping, and parking lot."
- .3 **Add** Paragraph to Section as follows:
DEPARTMENTAL REPRESENTATIVE FURNISHED ITEMS
- .1 Departmental Representative Responsibilities:
- .1 Arrange for delivery of shop drawings, product data, samples, manufacturer's instructions, and certificates to Contractor.
- .2 Deliver supplier's bill of materials to Contractor.
- .3 Arrange and pay for delivery to site in accordance with Progress Schedule.
- .4 Inspect deliveries jointly with Contractor.
- .5 Submit claims for transportation damage.
- .6 Arrange for replacement of damaged, defective or missing items.
- .7 Arrange for manufacturer's field services; arrange for and deliver manufacturer's warranties and bonds to Contractor.
- .2 Contractor Responsibilities:
- .1 Designate submittals and delivery date for each product in progress schedule.
- .2 Review shop drawings, product data, samples, and other submittals. Submit to Departmental Representative notification of observed discrepancies or problems anticipated due to non-conformance with Contract Documents.
- .3 Receive and unload products at site.
- .4 Inspect deliveries jointly with Departmental Representative; record shortages, and damaged or defective items.
- .5 Handle products at site, including uncrating and storage.
- .6 Protect products from damage, and from exposure to elements.
- .7 Assemble, install, connect, adjust, and finish products.
- .8 Provide installation inspections required by public authorities.
- .9 Repair or replace items damaged by Contractor or subcontractor on site (under their control).
- .3 Schedule of Departmental Representative-furnished items:

- .1 Fireplace.
- .2 SECTION 01 32 16.07 – CONSTRUCTION PROGRESS SCHEDULE - BAR (GANTT) CHART
 - .1 Ensure detailed Project Schedule includes, at minimum, milestone and activity types as follows:
 - .1 Award.
 - .2 Shop Drawings, Samples.
 - .3 Permits.
 - .4 Review of RTM fabrication at manufacturing location.
 - .5 Site installation of RTMs.
 - .6 Utility connection.
 - .7 RTM Exterior Finishing.
 - .8 Supplied equipment long delivery items.
 - .3 SECTION 01 78 00 – CLOSEOUT SUBMITTALS
 - .1 **Delete** items 1.5.6.6 ESA certification and 1.5.6.7 TSSA certification.
 - .4 SECTION 06 10 00 – ROUGH CARPENTRY
 - .1 **Revise** Item 3.4.1 to “Comply with requirements of NBC 2015 Part 9 supplemented by following paragraphs.”
 - .5 SECTION 26 50 00 – EXIT SIGNS
 - .1 **Delete** references to NFPA 101.
 - .6 SECTION 28 31 01 – FIRE ALARM SYSTEM (ADDRESSABLE, SINGLE STAGE)
 - .1 **Delete** Paragraph 2.6 GRAPHIC ANNUNCIATOR – PASSIVE TYPE.
 - .2 **Revise** references to Alberta Building Code (ABC) to the ABC 2014 Edition.
 - .3 **Revise** references to CAN/ULC-S537 to the 2013 Edition.
- 1.3 CHANGES TO DRAWINGS**
 - .1 SHEET A0.1 – LIST OF CONSULTANTS, LIST OF DRAWINGS, CODE REVIEW, GENERAL NOTES
 - .1 **Add** Occupancies to Code Review:
 - .1 Alpine Cottage: Occupancy 12.
 - .2 Bunkhouse: Occupancy 8.
 - .2 DRAWING A2.1 – ALPINE COTTAGE AND BUNKHOUSE NEW CONSTRUCTION FLOOR PLANS
 - .1 Detail 2:
 - .1 **Add** note stating, “Clearance to combustible material from the wood fireplace and chimney must respect those as specified by the manufacturer’s installation instructions”.
 - .3 DRAWING E1 – SITE PLAN AND SINGLE LINE DIAGRAM
 - .1 Refer to revised Drawing E1 as attached. Revisions are indicated in revision clouds.
 - .4 DRAWING E2 – ALPINE COTTAGE AND BUNK HOUSE CRAWLSPACE PLAN – ELECTRICAL AND RISER DIAGRAM
 - .1 Refer to revised Drawing E2 as attached. Revisions are indicated in revision clouds.

.5 DRAWING E3 – LIGHTING, POWER AND SYSTEMS

.1 Detail 3:

- .1 **Delete** requirement for CO detectors, connected to Fire Alarm System.
- .2 **Revise** all Smoke Alarms to Combination CO/Smoke Alarm units.
- .3 **Add** a horn-strobe combination to device Bunk Room 7.

END OF ADDENDUM NUMBER NO. 2

