



- NOTES: #
- ALL EQUIPMENT TO REMAIN UNLESS NOTED OTHERWISE.
 - EXISTING INSTRUMENT TRANSFORMERS TO BE REMOVED. COORDINATE WITH NL POWER.
 - COORDINATE REMOVAL OF THE EXISTING UTILITY METER WITH NL POWER. REMOVE EXISTING METER BASE AND ASSOCIATED WIRING AND CONDUITS.
 - DISCONNECT EXISTING BUILDING SERVICE ENTRANCE GROUNDING CONNECTION. REMOVE ASSOCIATED GROUNDING CONDUCTOR.
 - EXISTING PADMOUNT TRANSFORMER AND ASSOCIATED UNDERGROUND SECONDARY CABLES IN CONCRETE ENCASED DUCT BANK TO BE REMOVED.
 - EXISTING WIRING AND CONDUIT TO BE REMOVED.

EXISTING/DEMOLITION SINGLE LINE DIAGRAM



C01	18/10/18	ISSUED FOR TENDER	L.M.	NS
No.	Date	Description	Drawn by Dessiné par	Approved Approuvé

A B	Detail number Sheet number	A Numéro de détail B Numéro de la feuille
Linear dimensions in millimetres		Dimensions linéaires en millimètres
Consultant's Name Nom de l'expert-conseil		Eng. Stamp Sceau de l'ingénieur
SNC • LAVALIN SNC • LAVALIN Inc. Halifax, Nova Scotia, Canada Member of the SNC • LAVALIN Group		

Project title/Titre du projet
TERRA NOVA VISITOR CENTRE REHABILITATION UPGRADES
GLOVERTOWN, NL

Drawing title/Titre du dessin			
EXISTING/DEMOLITION SINGLE LINE DIAGRAM			
Designed by/Concept par S.M.		Date 2018/03/28	
Drawn by/Dessiné par S.M.		Date 2018/03/28	
Checked by/Vérifié par D.C. / J.L.		Date —	
Project No./No. du projet 1326	Scale/Echelle N.T.S.	Sheet No./ Nude la feuille	
Drawing Set No./No. de série du dessin E-03			