



SCALE: H: 1:250
V: 1:25



1. ALL NEWLY INSTALLED SANITARY SEWER PIPING TO CONSIST OF 100mm PVC DR35 UNLESS OTHERWISE STATED.
2. DISTRIBUTION FIELD CONSISTS OF 20 LATERALS BASED ON CLAYTON SOIL CLASSIFICATION. DISTRIBUTION FIELD MAY BE ADJUSTED DUE TO OBSERVED SOIL CONDITIONS AT THE DISCRETION OF THE ENGINEER.
3. REMOVE AND DISPOSE OF EXISTING MATERIAL AS REQUIRED TO FACILITATE CONSTRUCTION OF NEW SEPTIC SYSTEM.
4. CONTRACTOR TO REINSTATE ALL DISTURBED AREAS WITH 100mm TOPSOIL, HYDROSEED AND HAY MULCH UNLESS OTHERWISE STATED.
5. PROVIDE INSULATION ON PIPING BETWEEN SAMH AND DISTRIBUTION BOX.