



**RETURN BIDS TO:**  
**RETOURNER LES SOUMISSIONS À:**  
PWGSC/TPSGC Acquisitions Bid  
Receiving/Réception des Soumissions  
126 Prince William Street/  
126, rue Prince William  
Suite 14B  
Saint John  
New Brunswick  
E2L 2B6  
Bid Fax: (506) 636-4376

**SOLICITATION AMENDMENT**  
**MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

**Comments - Commentaires**

All enquiries are to be submitted in writing to the Contracting Offer, Janine Donovan: Email - janine.donovan@pwgsc.gc.ca.

**Vendor/Firm Name and Address**  
**Raison sociale et adresse du fournisseur/de l'entrepreneur**

**Issuing Office - Bureau de distribution**

Public Works Government Services Canada-Bid  
Receiving / Réception des soumissions  
126 Prince William Street/  
126, rue Prince William  
Suite 14B  
Saint John  
New Bruns  
E2L 2B6

<b>Title - Sujet</b> Closure Shoreward Gap-St John NB	
<b>Solicitation No. - N° de l'invitation</b> EB144-192031/A	<b>Amendment No. - N° modif.</b> 002
<b>Client Reference No. - N° de référence du client</b> EB144-192031	<b>Date</b> 2018-11-19
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWB-020-4368	
<b>File No. - N° de dossier</b> PWB-8-41064 (020)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2018-11-27</b>	
<b>Time Zone</b> Fuseau horaire Atlantic Standard Time AST	
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Donovan, Janine PWB	<b>Buyer Id - Id de l'acheteur</b> pwb020
<b>Telephone No. - N° de téléphone</b> (506) 639-0215 ( )	<b>FAX No. - N° de FAX</b> (506) 636-4376
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b>	

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

Solicitation No. - N° de l'invitation  
EB144-192031/A

Amd. No. - N° de la modif.  
002

Buyer ID - Id de l'acheteur  
PWB020

Client Ref. No. - N° de réf. du client  
R.099232.001

File No. - N° du dossier  
PWB-8-41064

CCC No./N° CCC - FMS No./N° VME

---

This Solicitation Amendment No. Two (2) is raised to include the following addendum no. 2.

The following addendum to the tender documents is effective immediately. This addendum shall form part of the contracts documents.

All other terms and conditions remain the same.

Addendum no. 2

1. **EXTENSION OF TIME**

Notice is hereby given that the time for the reception of tenders previously due November 22, 2018 is hereby extended to **14:00 hours, November 27, 2016**.

2. **INVITATION TO TENDER**

**REMOVE** "Appendix 1 – Combined Price Form" and **REPLACE WITH** the "Appendix 1 – Combined Price Form revised November 19, 2018".

Note: The Appendix 1 – Combined Price Form revised November 19, 2018 attached in this amendment is the Combined Price Form that **MUST** be submitted with your bid. Failure to comply with this requirement will result in your bid being deemed **non-responsive**.

3. **QUESTIONS AND ANSWERS**

Q1: The drawings note (sheet 2) that the anchor bolts and prefabricated anchor inserts to be disposed and replaced by new ones to match existing. Can you provide the length and nominal size?

A1: The existing guiderail post anchors are 25.4mm diameter and have an embedment of 200mm with a 100mm hook.

Q2: In drawing sheet no 5, it is mentioned that deteriorated reinforced steel to be removed and new ones to be installed in the existing deck by approved embedment methodology. Can you provide the approved method?

A2: Reinforcing steel in pristine condition may be left in place for reuse in new work. Careful removal of existing concrete is required to minimize any damage to components that will be reinstated in the new work. Where existing deteriorated reinforcing steel is found during concrete removals, or where reinforcing interferes with relocation of tie-rod bolts, Contractor is to propose an embedment methodology for installation of new reinforcing rebar to reinforce the concrete to full capacity of original steel (methodology to be approved by the Departmental Representative).

Q3: For the electrical services inside the concrete guard and inside electrical conduits, who is responsible for the disconnection and pulling of the cables, and if this is within the scope for how long can the facility provide a shut-down period?

A3: The electrical contractor is responsible for pulling of the cables. The work must be coordinated with the Departmental Representative (and the Owner's electrician) for disconnection and de-energizing of the wires. The terminal is fully active and will remain operational throughout the project.

Solicitation No. - N° de l'invitation  
EB144-192031/A

Amd. No. - N° de la modif.  
002

Buyer ID - Id de l'acheteur  
PWB020

Client Ref. No. - N° de réf. du client  
R.099232.001

File No. - N° du dossier  
PWB-8-41064

CCC No./N° CCC - FMS No./N° VME

---

Temporary electrical supply will be required during construction to minimize any interruption to electrical service.

Solicitation No. - N° de l'invitation  
EB144-192031/A

Amd. No. - N° de la modif.  
002

Buyer ID - Id de l'acheteur  
PWB020

Client Ref. No. - N° de réf. du client  
R.099232.001

File No. - N° du dossier  
PWB-8-41064

CCC No./N° CCC - FMS No./N° VME

**REVISED NOVEMBER 19, 2018**  
**APPENDIX 1 - COMBINED PRICE FORM**

- 1) The prices per unit will govern in establishing the Total Extended Amount. Any arithmetical errors in this Appendix will be corrected by Canada.
- 2) Canada may reject the bid if any of the prices submitted do not reasonably reflect the cost of performing the part of the work to which that price applies.

**LUMP SUM**

The Lump Sum Amount designates Work to which a Lump Sum Arrangement applies.

- (a) Work included in the Lump Sum Amount represents all work not included in the unit price table.

<b>LUMP SUM AMOUNT (LSA)</b> Excluding applicable tax(es)	Not applicable
--	----------------

**UNIT PRICE TABLE**

The Unit Price Table designates Work to which a Unit Price Arrangement applies.

- (a) Work included in each item is as described in the referenced specification section.
- (b) The Price per Unit shall not include any amounts for Work that is not included in that unit price Item.

Item Item	Specification Reference	Class of Labour, Plant or Material	Unit of Measur- ement	Estimated Quantity (EQ)	Price per Unit applicable taxe(s) extra (PU)	Extended amount (EQ x PU) applicable tax(es) extra
1		Mobilization and demobilization	Lump sum	1		
2	01 51 00	Site office	Lump sum	1		
3	35 31 24	Corestone	Tonnes	3,790		
4	35 31 24	Filterstone	Tonnes	2,255		
5	35 31 24	Armourstone (4-9 tonne)	Tonnes	9,355		
6	02 41 16	Demolition, removals and reinstatement	Lump sum	1		
7	03 30 00	Concrete Guard	Lump sum	1		
8	31 62 17	Steel sheet piling – supply	m <sup>2</sup>	373		
9	31 62 17	Steel sheet piling – install	m <sup>2</sup>	359		
10	31 62 17	Box piles – supply	Linear meters	186		
11	31 62 17	Box piles – install	Linear meters	186		
12	05 50 00	Miscellaneous metals	Lump sum	1		
<b>TOTAL EXTENDED AMOUNT (TEA)</b> Excluding applicable tax(es)						

<b>TOTAL BID AMOUNT (LSA +TEA)</b> Excluding applicable tax(es)
--