



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS Á:

Parks Canada Agency
1869 Upper Water Street,
Suite AH 201
Halifax, Nova Scotia
B3J 1S9

SOLICITATION AMENDMENT

MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaries

Vendor/Firm Name and Address
 Raison sociale et adresse du fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Parks Canada Agency
1869 Upper Water Street,
Suite AH 201
Halifax, Nova Scotia
B3J 1S9

Title-Sujet Visitor Centre Rehabilitation, Terra Nova National Park		
Solicitation No. - No. de l'invitation 5P201-18-0196/A		Amendment No./N° de modification de l'invitation 001
Client Ref. No. - No. de réf du client. 1326		Date: 29 November 2018
GETS Reference No. - No de reference de SEAG PW-18-00851230		
Solicitation Closes:		
at - á 14:00	on - le 06 December 2018	Time Zone - Fuseau horaire AST - HNA
F.O.B. - F.A.B.		
Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>		
Address Inquiries to: - Adresser toute demande de renseignements à : Jaime Creaser, Jaime.Creaser@canada.ca		
Telephone No. - No de téléphone (902) 426-7513		Fax No. - No de FAX: (902) 426-1775
Destination of Goods, Services, and Construction: Destinations des biens, services et construction: See Herein - Voir aux présentes		

TO BE COMPLETED BY THE BIDDER (type or print)
À ÊTRE COMPLÉTER PAR LE SOUMISSIONNAIRE (taper ou écrire en caractères d'imprimerie)

Vendor/Firm Name - Nom du fournisseur/de l'entrepreneur	
Address - Adresse	
Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur	
Titale - Titre	
Telephone No. - N° de téléphone: _____	
Facsimile No. - N° de télécopieur: _____	
Signature	Date

Solicitation No. - N° de l'invitation
5P201-18-0196/A

Amd. No. - N° de la modif.
001

Buyer - l'acheteur
Jaime Creaser

Client Ref. No. - N° de réf. du client
1326

File Name - Nom du dossier
Visitor Centre Rehabilitation, Terra Nova National Park

AMENDMENT 001

This amendment is being raised to modify the unit price table, specifications and to answer questions for solicitation 5P201-18-0196/A:

1. MODIFICATION TO APPENDIX 1 – UNIT PRICE TABLE

DELETE:

Unit Price Table in its entirety.

REPLACE WITH:

**THE ATTACHED PRICE FORM MUST BE USED IN ORDER FOR A BID TO BE DEEMED RESPONSIVE.
ANY BIDS SUBMITTED USING THE PREVIOUS PRICE FORM WILL NOT BE ACCEPTED.**

APPENDIX 1 - COMBINED PRICE FORM

- 1) The prices per unit will govern in establishing the Total Extended Amount. Any arithmetical errors in this Appendix will be corrected by Canada.
- 2) Canada may reject the bid if any of the prices submitted do not reasonably reflect the cost of performing the part of the work to which that price applies.

Note: Bidders are reminded that it is their responsibility to include in their bid all work as described in the drawings and specifications. Pricing for work not accounted for in the Unit Price Table including but not limited to Mobilization, De-Mobilization, etc. is to be included in the Lump Sum Table.

LUMP SUM

The Lump Sum Amount designates Work to which a Lump Sum Arrangement applies.

- (a) Work included in the Lump Sum Amount represents all work not included in the unit price table.

LUMP SUM AMOUNT (LSA) Excluding applicable tax(s)

UNIT PRICE TABLE

The Unit Price Table designates Work to which a Unit Price Arrangement applies.

- (a) Work included in each item is as described in the referenced specification section.
- (b) The Price per Unit shall not include any amounts for Work that is not included in that unit price

Item	Specification Reference	Class of Labour, Plant or Material	Unit of Measurement	Estimated Quantity (EQ)	Price per Unit applicable tax(s) extra (PU)	Extended amount (EQ x PU) applicable tax(s) extra
1	Civil	Supply & Placement of Topsoil	m ³	50		
2	Civil	Supply & Placement of Limestone	m ³	50		
3	Civil	Supply & Placement of Fertilizer	m ²	500		
4	Civil	Supply & Placement of Sod	m ²	500		
5	Civil	Supply & Placement of Storm Sewer: 100 mm dia. Solid PVC pipe	m	50		
6	Civil	Supply & Placement of Storm Sewer: 100 mm dia. Perf. PVC pipe	m	50		
7	Civil	Supply & Placement of 100 mm dia. PVC 90deg Bend	each	10		
8	Civil	Supply & Placement of 100 mm dia. PVC End Cap	each	10		
9	Civil	Removal of Asphalt Pavement	m ²	500		
10	Civil	Patching of Asphalt Pavement	m ²	500		
11	Civil	Imported Mass Common Fill	m ³	300		
12	Civil	Mass Common Excavation	m ³	300		

Item	Specification Reference	Class of Labour, Plant or Material	Unit of Measurement	Estimated Quantity (EQ)	Price per Unit applicable tax(s) extra (PU)	Extended amount (EQ x PU) applicable tax(s) extra
13	Div.3	610x610x38 Concrete Pavers	each	10		
14	Div.6	Replace Exist. Roof Sheathing	m ²	25		
15	Div.6	Replace Exist. Roof Facia and Rake Board	m	20		
16	Div.6	Replace Exist. Exterior Door Trim	m	5		
17	Div.6	Replace Exist. Exterior Door Sill	m	5		
18	Div.6	Replace Exist. Wood Deck Boards	m ²	25		
19	Div.6	Replace Exist. Roof Sheathing	m ²	25		
20	Div.7	Replace Exist. Asphalt Shingle	m ²	25		
21	Div.6	Replace Exist. Wood Siding	m ²	25		
22	Div.6	Replace Exist. Wood Soffit	m ²	25		
23	Div.6	Supply and build new fence and gate.	m	16		
24	Div.8	Replace glass and frame with single glazed window in pressed steel frame.	each	1		
25	Div.10	Scrape existing paint and make good. Paint exterior and interior of tanks PT5.	m ²	25		
26	Civil	Rock-breaking.	m ³	100		
TOTAL EXTENDED AMOUNT (TEA)						
Excluding applicable tax(s)						
TOTAL BID AMOUNT (LSA +TEA)						
Excluding applicable tax(s)						

2. MODIFICATION TO SPECIFICATIONS

Specification section 01 10 10 – General Instructions

ADD:

Item 1.1.4 Work under this project is to be carried out in a national park and environmental protection must be given high priority by all staff involved in the work. Perform work in accordance with the Canada National Parks Act and Regulations. <https://laws-lois.justice.gc.ca/eng/acts/N-14.01/>.

Specification section 01 35 29 – Health and Safety Requirements

DELETE:

Item 1.4.1 in its entirety.

DELETE:

Item 1.4.2 in its entirety.

DELETE:

Item 1.4.3 in its entirety.

ADD:

Item 1.11.9 Take all necessary precautions to ensure there are no safety concerns related to visitors of the Park.

Specification section 01 35 43 – Environmental Procedures

DELETE:

In its entirety

REPLACE WITH:

Revised specification section 01 35 43 – Environmental Procedures (see folder DSP 001 5P201-18-0196A).

Specification section 01 50 00 – Temporary Facilities and Controls

ADD:

Item 1.1.4 Vehicular traffic and staging areas for material and equipment to be restricted to present day road ways and disturbed areas.

ADD:

Item 1.1.5 Reduced speeds to be maintained on all roadways. Yield to pedestrians if present.

ADD:

Item 1.3.4 Laydown and storage areas to be rehabilitated after use.

ADD:

Item 1.7.3.1 Exterior lighting shall comply with the 2016 Guidelines and Specifications for Outdoor Lighting at Parks Canada.

Specification section 01 74 22 – Construction Demolition Waste Management

ADD:

Item 1.3.8 Disposing of unused concrete and cement within Park boundaries is not allowed.

Solicitation No. - N° de l'invitation
5P201-18-0196/A

Amd. No. - N° de la modif.
001

Buyer - l'acheteur
Jaime Creaser

Client Ref. No. - N° de réf. du client
1326

File Name - Nom du dossier
Visitor Centre Rehabilitation, Terra Nova National Park

ADD:

Item 1.3.9 All construction sites must be equipped with containers suitable for the secure, temporary storage of hazardous wastes, separated by type.

3. QUESTIONS AND ANSWERS

Q1. In the unit price table – item No. 2 – Supply and placement of limestone. The unit of measure is shown to be m³. Should this be m² instead?

A1. This is limestone gravels and the m³ unit is correct.

ALL OTHER TERMS AND CONDITONS REMAIN THE SAME.
