



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works & Government Services
Canada/Réception des soumissions Travaux publics et
Services gouvernementaux Canada

1713 Bedford Row
Halifax, N.S./Halifax, (N.E.)

Halifax
Nova Scotia
B3J 1T3

Bid Fax: (902) 496-5016

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Atlantic Region Acquisitions/Région de l'Atlantique
Acquisitions
1713 Bedford Row
Halifax, N.S./Halifax, (N.E.)
Halifax
Nova Scot
B3J 1T3

Title - Sujet Hampton Harbour Approach	
Solicitation No. - N° de l'invitation EB144-192089/A	Amendment No. - N° modif. 006
Client Reference No. - N° de référence du client EB144-19-2089	Date 2018-11-29
GETS Reference No. - N° de référence de SEAG PW-\$PWA-110-5819	
File No. - N° de dossier PWA-8-80086 (110)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2018-12-04	
Time Zone Fuseau horaire Atlantic Standard Time AST	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Collier (PWA), Susan	Buyer Id - Id de l'acheteur pwa110
Telephone No. - N° de téléphone (902) 401-3352 ()	FAX No. - N° de FAX (902) 496-5016
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

This Solicitation Amendment 006 is being raised to answer questions from potential bidder as follows:

Question 1:

Addendum #3 includes an attachment from Amec Foster Wheeler. This attachment contains the geotechnical site investigation for Hampton Wharf which some of the lettering within the text is not shown. Can you provide a report with all the wording, and text visible to read?

Answer 1:

See Amendment 005. There was a revised Geotechnical Report attached.

Question 2:

Does the cash allowance valued at \$10,000 include temporary power for the fisherman during the construction phase, or is the contractor required to provide temporary power until the new power pole is installed?

Answer 2:

Cash Allowance does not include temporary power.

Question 3:

Can you clarify the grade of steel for the Steel Thread Tie Rods? Detail 3/7 on Sheet 08 states 45mm DIA. Thread Bar Tie Rods Grade 75, while Section 05 50 00 in the specification states Grade 80?

Answer 3:

The steel tie rods are to be Grade 80.

Question 4:

Are turnbuckles required for the tie rod assembly or will you allow tie rods that are of full length?

Answer 4:

Full length tie rods are permitted.

Question 5:

Are all the materials associated the tie rod assembly (nuts, plates, and washers, tie rods) to be bare steel or galvanized? If there are any components that come in contact that are of different finishes (galvanized, bare steel), what are your requirements to provide isolation between the two materials?

Answer 5:

All material associated with the tie rod assembly are to be plain carbon steel.

Question 6:

Section 05 50 00 states that tie rods are to be preassembled, marked, and tested in the shop. Is this requirement for only one tie rod, or for all twenty one tie rods?

Answer 6:

Where couplers/sleeves are utilized, all tie rods to be preassembled, marked and tested in the shop.

Question 7:

Are the 45 mm Tie Rods and Associated Hardware Galvanized?

Answer 7:

Tie rods and Associated Hardware are not galvanized.

ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME.