



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Public Works and Government Services Canada
ATB Place North Tower
10025 Jasper Ave./10025 ave. Jasper
5th floor/5e étage
Edmonton
Alberta
T5J 1S6
Bid Fax: (780) 497-3510

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada
ATB Place North Tower
10025 Jasper Ave./10025 ave Jasper
5th floor/5e étage
Edmonton
Alberta
T5J 1S6

Title - Sujet Waterton Alpine Stables Building	
Solicitation No. - N° de l'invitation EP922-191669/A	Amendment No. - N° modif. 005
Client Reference No. - N° de référence du client PC	Date 2018-11-30
GETS Reference No. - N° de référence de SEAG PW-\$PWU-066-11481	
File No. - N° de dossier PWU-8-41142 (066)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2018-12-04	Time Zone Fuseau horaire Mountain Standard Time MST
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Lee, Mony	Buyer Id - Id de l'acheteur pwu066
Telephone No. - N° de téléphone (780) 224-6675 ()	FAX No. - N° de FAX (780) 497-3510
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation
EP922-191669/A

Amd. No. - N° de la modif.
005

Buyer ID - Id de l'acheteur
pwu066

Client Ref. No. - N° de réf. du client
PCA EP922-191669

File No. - N° du dossier
PWU-8-41142

CCC No./N° CCC - FMS No./N° VME

SOLICITATON AMENDMENT No. 005

The following question and answer are address to the specifications for clarification purposes only.

Question1. In Alpine Cottage and Bunkhouse there are windows that require egress that are spec'd as awning windows, awnings do not meet egress code any more. We would suggest changing the awning portion to casement which will allow for egress. W2 would have to be reduced in width to 1016mm as a casement. W3 would remain as sized on plan. Please see attached both suggested changes as Egress meeting options. Please advise if it is acceptable.

Response: The use of casement windows in the bedrooms is acceptable. Any W3 window not in the bedrooms should remain as an awning.

All other terms and conditions of the Invitation to Tender remain unchanged.