



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Réception des soumissions - TPSGC / Bid Receiving -
PWGSC
1550, Avenue d'Estimauville
1550, D'Estimauville Avenue
Québec
Québec
G1J 0C7

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Title - Sujet Const Extension Brise-LamesRimouski		
Solicitation No. - N° de l'invitation F3731-180099/A		Amendment No. - N° modif. 006
Client Reference No. - N° de référence du client PW-\$QCM-032-17532		Date 2018-11-30
GETS Reference No. - N° de référence de SEAG PW-\$QCM-032-17532		
File No. - N° de dossier QCM-8-41185 (032)	CCC No./N° CCC - FMS No./N° VME	
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2018-12-07		Time Zone Fuseau horaire Heure Normale du l'Est HNE
F.O.B. - F.A.B.		
Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>		
Address Enquiries to: - Adresser toutes questions à: Girard, Isabelle		Buyer Id - Id de l'acheteur qcm032
Telephone No. - N° de téléphone (418) 649-2847 ()		FAX No. - N° de FAX (418) 648-2209
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:		

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Issuing Office - Bureau de distribution
TPSGC-PWGSC
601-1550, Avenue d'Estimauville
Québec
Québec
G1J 0C7

Sollicitation No. – N° de l'invitation
F3731-180099/A
Client Ref. No. – N° de réf. du client
F3731-180099

Amd. No. – N° de la modif.
006
File No. – N° du dossier
QCM-8-41185

Buyer ID – Id de l'acheteur
QCM032
N° CCC / CCC No./ N° VME - FMS

AMENDMENT 006

TITLE : Breakwater extension, Rimouski est, Bas St-Laurent

Included in the present amendment:

1. Question and answer 10 and 11
-

QUESTION AND ANSWER:

Question 10 : In response to question # 9, it is noted that the selected quarry must be derived from a geological formation consisting of a minimum of 90% quartz. The geological maps as well as the descriptions of the different geological formations of Quebec do not have all the quartz and / or SiO₂ contents. In addition, a stone can be composed of 90% quartz grains in a calcareous matrix. The resistance of this type of rock may be less important than a stone that is composed of 90% quartz grains in a siliceous matrix. To determine the quartz content of a stone, it is essential to have a thin, polished blade. In the current period, it is impossible to perform a petrographic examination. How should we proceed?

Answer 10 : Please refer to question #9. We believe that the information contained in scientific reports (available on the internet) concerning the various geological formations composing Quebec quarries are sufficient to evaluate the average percentage of quartz and establish a bid respecting plans and specifications. However, the tests with thin polished blades will be required by DFO to demonstrate the percentage of quartz before beginning of stone production. As for the other criteria for rock quality, please refer to the specifications section 35 31 24. A calcareous rock may not respect, amongst others, the water absorption criterion or the wear resistance. These standard tests are usually already available for all quarries.

Question 11 : In the event that the density of the stone exceeds the upper limit of 2.85 established in Section 35 31 24, is the payment of these stones maximized at that limit or does Canada make the payment according to the actual density of the stone used?

Answer 11 : Stone will be paid by the metric ton whatever the stone density.

*** All other clauses and conditions remain unchanged ***