

QUESTIONS AND ANSWERS

Q1. Please specify the surface preparation requirements for the structural steel sleepers and associated steel for the new launching ramp in Kenora (bare, galvanized, primed, painted, etc.).

A1. ANS: The steel sleepers and associated steel are to be left bare