

1) The plans do not show the location of the electrical or the number of outlets.  
Normally we provide 3 outlets and locate them on the center spine is this suitable?

Three outlets will be suitable. However, we are not locating the powered panels on the spine of the workstations. They will, for the most part, be located directly in front of the employee's main work table.

1) Les plans n'indiquent ni l'emplacement ni le nombre de prises électriques.  
Normalement, nous fournissons trois prises situées sur la colonne centrale; est-ce acceptable?

Trois prises sont acceptables. Toutefois, nous ne plaçons pas de fiche avec du courant électrique sur la colonne centrale du poste de travail. Dans la plupart des cas, elles se trouvent directement à l'avant de la table de travail principale de l'employé.