



**RETURN BIDS TO:**

**RETOURNER LES SOUMISSIONS À:**

Public Works and Government Services Canada  
ATB Place North Tower  
10025 Jasper Ave./10025 ave. Jasper  
5th floor/5e étage  
Edmonton  
Alberta  
T5J 1S6  
Bid Fax: (780) 497-3510

**SOLICITATION AMENDMENT  
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

**Comments - Commentaires**

**Vendor/Firm Name and Address**  
**Raison sociale et adresse du**  
**fournisseur/de l'entrepreneur**

**Issuing Office - Bureau de distribution**  
Public Works and Government Services Canada  
ATB Place North Tower  
10025 Jasper Ave./10025 ave Jasper  
5th floor/5e étage  
Edmonton  
Alberta  
T5J 1S6

<b>Title - Sujet</b> Waterton Alpine Stables Building	
<b>Solicitation No. - N° de l'invitation</b> EP922-191669/A	<b>Amendment No. - N° modif.</b> 007
<b>Client Reference No. - N° de référence du client</b> PC	<b>Date</b> 2018-12-03
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWU-066-11481	
<b>File No. - N° de dossier</b> PWU-8-41142 (066)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2018-12-07</b>	<b>Time Zone</b> <b>Fuseau horaire</b> Mountain Standard Time MST
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Lee, Mony	<b>Buyer Id - Id de l'acheteur</b> pwu066
<b>Telephone No. - N° de téléphone</b> (780) 224-6675 ( )	<b>FAX No. - N° de FAX</b> (780) 497-3510
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b>	

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

Solicitation No. - N° de l'invitation  
EP922-191669/A

Amd. No. - N° de la modif.  
007

Buyer ID - Id de l'acheteur  
pwu066

Client Ref. No. - N° de réf. du client  
PCA EP922-191669

File No. - N° du dossier  
PWU-8-41142

CCC No./N° CCC - FMS No./N° VME

---

## **SOLICITATON AMENDMENT No. 007**

See attached Addendum 004.

All other terms and conditions of the Invitation to Tender remain unchanged.

**Part 1 General**

.1 This addendum consists of two (2) pages.

.2 Q: We request an extension to tender closing.

.1 A: Tender period will be extended to December 07, 2018.

**1.2 CHANGES TO THE PROJECT MANUAL – ALPINE COTTAGE AND BUNKHOUSE**

.1 SECTION 09 91 00 – PAINTING

.1 Add – Item 3.5.10. Application

.1 Paint shiplap pine after installation.

**1.3 CHANGES TO THE PROJECT MANUAL - SADDLING BARN, BOARDING BARN & SITE WORK**

.1 SECTION 09 91 00 – PAINTING

.1 **Add** – item 2.5.5. – Plywood walls and ceilings

.1 INT 6.4J – Polyurethane varnish, G4 (satin-like) finish

.1 Apply 3 coats

**1.4 CHANGES TO DRAWINGS - SADDLING BARN, BOARDING BARN & SITE WORK**

.1 Refer to Drawing 1/A3.1 - Keynote 2

.1 **Revise** - FIBRE CEMENT SOFFIT. FACTORY FINISH COLOUR SIMILAR TO; BENJAMIN MOORE HC-5.

**1.5 CLARIFICATIONS – ARCHITECTURAL - ALPINE COTTAGE AND BUNKHOUSE**

.1 Q: is the crawl space considered confined space? If so, is there a confined space job procedure/rescue procedure in place already?

.1 Refer to OHS guidelines regarding confined space. No Job or Rescue procedures are in place.

.2 Q: In Alpine Cottage and Bunkhouse there are windows that require egress that are spec'd as awning windows, awnings do not meet egress code any more. We would suggest changing the awning portion to casement which will allow for egress. W2 would have to be reduced in width to 1016mm as a casement. W3 would remain as sized on plan. Please see attached both suggested changes as Egress meeting options. Please advise if it is acceptable.

.1 A: The use of casement windows in the bedrooms is acceptable. Any W3 window not in the bedrooms should remain as an awning. Please see attached marked up elevation with specific directions for one of the W2 windows.

**1.6 CLARIFICATIONS – MECHANICAL - ALPINE COTTAGE AND BUNKHOUSE**

.1 Q: Looking through the documents, there are two small sump pumps required:

P-1 Sump Pump for the Alpine Cottage Crawl Space called up as a 1/2HP, 120/1/60 plug in style pump

P-2 Sump Pump for the Bunk House Crawl Space called up as a 1/2HP, 120/1/60 plug in style pump

We cannot find any other information on the requirements for the pumps.

What flow rate and TDH are required for the pumps?

Is there any specification at all on the pumps. Any design at all on the pumps?

Couldn't find anything other than what was written in the "Motor schedule Alpine Cottage and Bunk House", as listed above.

Please confirm the sump pump are required or not, if so, please provide a voltage and a horsepower.

- .1        A: Yes, sump pumps are required. Refer to schedules on drawing M-3 and Technical Specification Section 22 10 10 Plumbing Pumps.

-    **END OF ADDENDUM NO. 04**  -

[illegible]