



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Public Works and Government Services Canada
ATB Place North Tower
10025 Jasper Ave./10025 ave. Jasper
5th floor/5e étage
Edmonton
Alberta
T5J 1S6
Bid Fax: (780) 497-3510

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada
ATB Place North Tower
10025 Jasper Ave./10025 ave Jasper
5th floor/5e étage
Edmonton
Alberta
T5J 1S6

Title - Sujet Waterton Alpine Stables Building	
Solicitation No. - N° de l'invitation EP922-191669/A	Amendment No. - N° modif. 007
Client Reference No. - N° de référence du client PC	Date 2018-12-03
GETS Reference No. - N° de référence de SEAG PW-\$PWU-066-11481	
File No. - N° de dossier PWU-8-41142 (066)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2018-12-07	Time Zone Fuseau horaire Mountain Standard Time MST
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Lee, Mony	Buyer Id - Id de l'acheteur pwu066
Telephone No. - N° de téléphone (780) 224-6675 ()	FAX No. - N° de FAX (780) 497-3510
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation
EP922-191669/A

Amd. No. - N° de la modif.
007

Buyer ID - Id de l'acheteur
pwu066

Client Ref. No. - N° de réf. du client
PCA EP922-191669

File No. - N° du dossier
PWU-8-41142

CCC No./N° CCC - FMS No./N° VME

MODIFICATION DE L'INVITATION No. 007

Voir addenda ci-joint 004.

Toutes les autres modalités et conditions de l'Appel d'offres restent inchangées.

Part 1 General

.1 This addendum consists of two (2) pages.

.2 Q: We request an extension to tender closing.

.1 A: Tender period will be extended to December 07, 2018.

1.2 CHANGES TO THE PROJECT MANUAL – ALPINE COTTAGE AND BUNKHOUSE

.1 SECTION 09 91 00 – PAINTING

.1 Add – Item 3.5.10. Application

.1 Paint shiplap pine after installation.

1.3 CHANGES TO THE PROJECT MANUAL - SADDLING BARN, BOARDING BARN & SITE WORK

.1 SECTION 09 91 00 – PAINTING

.1 **Add** – item 2.5.5. – Plywood walls and ceilings

.1 INT 6.4J – Polyurethane varnish, G4 (satin-like) finish

.1 Apply 3 coats

1.4 CHANGES TO DRAWINGS - SADDLING BARN, BOARDING BARN & SITE WORK

.1 Refer to Drawing 1/A3.1 - Keynote 2

.1 **Revise** - FIBRE CEMENT SOFFIT. FACTORY FINISH COLOUR SIMILAR TO; BENJAMIN MOORE HC-5.

1.5 CLARIFICATIONS – ARCHITECTURAL - ALPINE COTTAGE AND BUNKHOUSE

.1 Q: is the crawl space considered confined space? If so, is there a confined space job procedure/rescue procedure in place already?

.1 Refer to OHS guidelines regarding confined space. No Job or Rescue procedures are in place.

.2 Q: In Alpine Cottage and Bunkhouse there are windows that require egress that are spec'd as awning windows, awnings do not meet egress code any more. We would suggest changing the awning portion to casement which will allow for egress. W2 would have to be reduced in width to 1016mm as a casement. W3 would remain as sized on plan. Please see attached both suggested changes as Egress meeting options. Please advise if it is acceptable.

.1 A: The use of casement windows in the bedrooms is acceptable. Any W3 window not in the bedrooms should remain as an awning. Please see attached marked up elevation with specific directions for one of the W2 windows.

1.6 CLARIFICATIONS – MECHANICAL - ALPINE COTTAGE AND BUNKHOUSE

.1 Q: Looking through the documents, there are two small sump pumps required:

P-1 Sump Pump for the Alpine Cottage Crawl Space called up as a 1/2HP, 120/1/60 plug in style pump

P-2 Sump Pump for the Bunk House Crawl Space called up as a 1/2HP, 120/1/60 plug in style pump

We cannot find any other information on the requirements for the pumps.

What flow rate and TDH are required for the pumps?

Is there any specification at all on the pumps. Any design at all on the pumps?

Couldn't find anything other than what was written in the "Motor schedule Alpine Cottage and Bunk House", as listed above.

Please confirm the sump pump are required or not, if so, please provide a voltage and a horsepower.

- .1 A: Yes, sump pumps are required. Refer to schedules on drawing M-3 and Technical Specification Section 22 10 10 Plumbing Pumps.

- **END OF ADDENDUM NO. 04** -

