



**RETURN BIDS TO:**

**RETOURNER LES SOUMISSIONS Á:**

Parks Canada Agency  
220 4 Ave SE, Suite 720  
Calgary, AB T2G 4X3

**AMENDMENT / MODIFICATION**

**002**

**Tender To: Parks Canada Agency**

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services, and construction listed herein and on any attached sheets at the price(s) set out therefor.

**Soumission aux: l'Agence Parcs Canada**

Nous offrons par la présente de vendre à Sa Majesté la Reine du Chef du Canada, aux conditions énoncées ou incluses par référence dans la présente at aux annexes ci-jointes, les biens, services et construction énumérés ici et sur toute feuille ci-annexée, au(x) prix indiqué(s).

Comments - Commentaries

**Vendor/Firm Name and Address**

Raison sociale et adresse du fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

**Parks Canada Agency**  
**220 4 Ave SE, Suite 720**  
**Calgary, AB T2G 4X3**

<b>Title-Sujet</b> Whirlpool Residence Foundation Replacement – Riding Mountain National Park	
<b>Solicitation No. - No. de l'invitation</b> 5P420-18-0403/A	<b>Date:</b> December 4, 2018
<b>GETS Reference No. – No de reference de SEAG</b> PW-18-00850372	<b>Amendment No. - N° de la modif.</b> 2
<b>Solicitation Closes:</b>	
<b>at – á</b> 02:00 PM	<b>on – le</b> December 11, 2018
<b>Time Zone - Fuseau horaire</b> MST - HNR	
<b>F.O.B. - F.A.B.</b>	
<b>Plant-Usine:</b> <input type="checkbox"/>	<b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>
<b>Address Inquiries to: - Adresser toute demande de renseignements à :</b>	
Rebecca Chen <a href="mailto:rebecca.chen2@canada.ca">rebecca.chen2@canada.ca</a>	
<b>Telephone No. - No de téléphone</b> (587) 439-3529	<b>Fax No. – No de FAX:</b> 1-866-246-6893
<b>Destination of Goods, Services, and Construction:</b> <b>Destinations des biens, services et construction:</b>	
See Herein – Voir ici	

**TO BE COMPLETED BY THE BIDDER (type or print)**

<b>Vendor/Firm Name</b>	
<b>Address - Adresse</b>	
<b>Name of person authorized to sign on behalf of the Vendor/Firm</b> <b>Nom de la personne autorisée a signer au nom du fournisseur/ de l'entrepreneur</b>	
<b>Titale - Titre</b>	
<b>Telephone No. - N° de telephone:</b> _____	
<b>Facsimile No. - N° de télécopieur:</b> _____	
<b>Signature</b>	<b>Date</b>

## Amendment 02

This amendment is being raised to distribute information from the site visit and to distribute questions and answers.

### A) SITE VISIT ATTENDEES

Vendor	Representative's Name
Gardon Construction	Shane Johnson
Collyer Construction	Mike Collyer
Jacobson Commercial	Mike Hardy
Premier Commercial	Brent Bromley
DG Konkin Construction	Brett Konkin

Contact information for the attendees are available upon request and approval from the vendors.

### B) TENDER PACKAGE REVISIONS

**ADD:** DSP2\_18-0403: Designated Substance Report\_09Apr18.pdf

### SPECIFICATIONS

**DELETE:** Section 02 41 13 Selective Demolition, 1.4.2.1 Submit drawings stamped and signed by professional engineer registered or licensed in Province of Manitoba, Canada.

### C) QUESTIONS & ANSWERS

**Q1** Will hand and mini excavator careful shallow depth digging be required, as outlined in section 31 00 99, Earthwork for Minor Work?

**A1** In specifications section 31 00 99 omit 3.3.2 (3.3.2.1 and .3 still apply). Hand tools and shallow-depth machine excavation are not required. In specifications section 31 00 99 omit 3.3.5 and 3.4.2. Careful shallow depth machine excavation is not required.

**Q2** Is an engineered demolition plan necessary?

**A2** No, demolition drawings are not necessary and is to be removed. See B) Tender Package Revisions.

**Q3** The waste management goals and audits outlined in section 01 74 1 may be difficult to achieve in rural Manitoba, will proof of recycling such as weigh bills be required?

**A3** With reference to Section 01 74 21 Construction/Demolition Waste Management and Disposal, the departmental representative will work with the contractor to understand where the materials will be disposed and whether or not waybills, receipts and/or scale tickets are available. The Departmental Representative will not set waste audit acceptable values.

**Q4** Will a designated substance report be required?

**A4** No, one has been produced. Please see DSP2\_18-0403

**Q5** What is the plan for the two decks on the house?

**A5** The front porch is an integral part of the structure and will have to be anchored and moved with the building. The front stairs and back deck and stairs are to be removed, set aside and reattached when the structure is set back on the new foundation.

**Q6** Whose responsibility will it be to reinstall basement shelving?

**A6** Parks Canada will remove all basement shelving and reinstall when the contract is complete.

**Q7** Do the old windows have to be reinstalled?

**A7** Parks Canada will remove the basement windows, repair and repaint and re-install after construction is complete. All utilities currently running through windows are to be sleeved into the concrete.

**Q8** Will the contract include mudding and painting the gypsum board?

**A8** No. Parks Canada will mud and paint the gypsum board.

**Q9** Will the basement ceiling be fixed with gypsum board?

**A9** No

**Q10** Will the insulation and gypsum board extend to the rim joists?

**A10** Yes

**Q11** Parks Canada will remove the historic masonry, as soon as possible in the spring of 2019, and replace it after construction is complete, does this include the parging provided for above grade concrete?

**A11** Yes

**All other terms and conditions remain unchanged.**