



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS Á:

Parks Canada Agency
1869 Upper Water Street,
Suite AH 201
Halifax, Nova Scotia
B3J 1S9

SOLICITATION AMENDMENT

MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaries

Vendor/Firm Name and Address
 Raison sociale et adresse du fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Parks Canada Agency
1869 Upper Water Street,
Suite AH 201
Halifax, Nova Scotia
B3J 1S9

Title-Sujet Visitor Centre Rehabilitation, Terra Nova National Park		
Solicitation No. - No. de l'invitation 5P201-18-0196/A		Amendment No./N° de modification de l'invitation 004
Client Ref. No. - No. de réf du client. 1326		Date: 11 December 2018
GETS Reference No. - No de reference de SEAG PW-18-00851230		
Solicitation Closes:		
at - á 14:00	on - le 18 December 2018	Time Zone - Fuseau horaire AST - HNA
F.O.B. - F.A.B.		
Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>		
Address Inquiries to: - Adresser toute demande de renseignements à : Jaime Creaser, Jaime.Creaser@canada.ca		
Telephone No. - No de téléphone (902) 426-7513		Fax No. - No de FAX: (902) 426-1775
Destination of Goods, Services, and Construction: Destinations des biens, services et construction: See Herein - Voir aux présentes		

TO BE COMPLETED BY THE BIDDER (type or print)
À ÊTRE COMPLÉTER PAR LE SOUMISSIONNAIRE (taper ou écrire en caractères d'imprimerie)

Vendor/Firm Name - Nom du fournisseur/de l'entrepreneur	
Address - Adresse	
Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur	
Titale - Titre	
Telephone No. - N° de téléphone: _____	
Facsimile No. - N° de télécopieur: _____	
Signature	Date

AMENDMENT 004

This amendment is being raised to modify the bid closing date, the specifications, and drawings for solicitation 5P201-18-0196/A:

1. BID CLOSING DATE

The closing date for tender 5P201-18-0196/A is extended from 13 December 2018 until 18 December 2018 at 14:00 Atlantic Standard Time (AST).

2. MODIFICATION TO SPECIFICATIONS

CIVIL

Section 02 50 00 – Site Remediation

Add new section – 02 50 00 Site Remediation, (see folder DSP 004 5P201-18-0196A).

Section 31 23 33 – Excavation, Trenching and Backfilling

Add new section 31 23 33 – Excavation, Trenching and Backfilling, (see folder DSP 004 5P201-18-0196A).

Section 32 01 16 – Reshaping and Patching Asphalt Pavement

Add new section 32 01 16 Reshaping and Patching Asphalt Pavement, (see folder DSP 004 5P201-18-0196A).

Section 32 11 16 – Selected Base and Sub Base Materials

Add new section 32 11 16 – Selected Base and Sub Base Materials, (see folder DSP 004 5P201-18-0196A).

Section 32 92 23 – Sodding

Add new section 32 92 23 – Sodding, (see folder DSP 004 5P201-18-0196A).

Section 33 31 11 – Sanitary Utility Sewage Piping

Add new section 33 31 11 – Sanitary Utility Sewage Piping, (see folder DSP 004 5P201-18-0196A).

3. MODIFICATION TO DRAWINGS

MECHANICAL

Sheet H-06 New HVAC Plan

Clarification: Condensing Units CU-1 and CU-2 to be individually piped to their respective coils in their AHU's.

ELECTRICAL

Sheet E-04 – Proposed Single Line Diagram

Replace secondary feeders from new utility transformer 'P_TX-1' to main distribution panel 'HDA' from 2x(3#500MCM + 1#3 Bond) to 3x(3#350MCM + 1#3 bond).

ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME.
