



1 DUCT SIZE REVISION
M3.6 SCALE: 1:100

GRILLE, DIFFUSER & LOUVER SCHEDULE

TYPE	SERVICE	DESCRIPTION	REMARKS
A	SUPPLY AIR	SQUARE CONE DIFFUSER. T-BAR LAY-IN.	REFER TO MECHANICAL DRAWINGS FOR SIZES AND LOCATIONS. COLORS AND FINISHES BY ARCHITECTURAL.
B	SUPPLY AIR	SINGLE DEFLECTION REGISTER C/W DAMPER. STEEL CONSTRUCTION. SPIRAL DUCT MOUNTING FRAME.	DIFFUSER COMPLETE WITH INTEGRAL BALANCING DAMPER. REFER TO MECHANICAL DRAWINGS FOR SIZES AND LOCATIONS. COLORS AND FINISHES BY ARCHITECTURAL.
C	SUPPLY AIR	SINGLE DEFLECTION REGISTER C/W DAMPER. STEEL CONSTRUCTION. FLAT SURFACE MOUNTED.	REFER TO MECHANICAL DRAWINGS FOR SIZES AND LOCATIONS. COLORS AND FINISHES BY ARCHITECTURAL.
D	RETURN AIR	EGG CRATE GRILLE. T-BAR LAY-IN.	REFER TO MECHANICAL DRAWINGS FOR SIZES AND LOCATIONS. COLORS AND FINISHES BY ARCHITECTURAL.
E	RETURN AIR	EGG CRATE GRILLE. FLAT SURFACE MOUNTED.	REFER TO MECHANICAL DRAWINGS FOR SIZES AND LOCATIONS. COLORS AND FINISHES BY ARCHITECTURAL.

PLOTTED ON 2018-12-6 BY MICHAEL REIMER
DOCUMENT SAVED IN H: \\11800\11838\00\00 DRAWINGS\03 MECH\11838_M3.6.DWG

11838-01



MCW / AGE

Consulting Professional Engineers

210-1821 Wellington Avenue

Winnipeg, Manitoba, R3H 0G4

Phone - (204) 779-7900 Fax - (204) 779-1119

E-Mail: mcw_wpg@mcw.com

PROJECT:

ACTIVITY BASED WORKPLACE FIT-UP
269 MAIN STREET

REF. DWG. NO.

M3.6

DESCRIPTION:

FIFTH FLOOR VENTILATION REVISIONS

DWG. NO.

RM-4

DATE:

2018-12-06

DRAWN BY:

MR

SCALE:

AS NOTED

ISSUED WITH:

ADD#02ME