



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada

1713 Bedford Row

Halifax, N.S./Halifax, (N.É.)

Halifax

Nova Scotia

B3J 1T3

Bid Fax: (902) 496-5016

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address

Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Atlantic Region Acquisitions/Région de l'Atlantique
Acquisitions

1713 Bedford Row

Halifax, N.S./Halifax, (N.É.)

Halifax

Nova Scot

B3J 1T3

Title - Sujet Prefabricated Storage Shelter	
Solicitation No. - N° de l'invitation W355B-194459/A	Amendment No. - N° modif. 002
Client Reference No. - N° de référence du client W355B-19-4459	Date 2018-12-13
GETS Reference No. - N° de référence de SEAG PW-\$HAL-307-10557	
File No. - N° de dossier HAL-8-81177 (307)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2019-01-03	Time Zone Fuseau horaire Atlantic Standard Time AST
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Stevenson, Jacquelyn	Buyer Id - Id de l'acheteur hal307
Telephone No. - N° de téléphone (902) 403-3520 ()	FAX No. - N° de FAX (902) 496-5016
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation

W355B-194459/A

Client Ref. No. - N° de réf. du client

W355B-194459

Amd. No. - N° de la modif.

00 2

File No. - N° du dossier

HAL-8-81177

Buyer ID - Id de l'acheteur

HAL307

CCC No./N° CCC - FMS No./N° VME

AMENDMENT 002

Amendment 002 is being raised for the following:

Question: If we can provide a better truss spacing while still exceeding all of the local and national building code requirements would this be an acceptable solution than the 6'oc truss spacing that the bid calls out for

Answer: Maximum acceptable truss spacing is 6', however you can be less than 6' as long as all other codes are met.

All other Terms & Conditions remain the same.